


COOLANT REPORT

THUNDER SPIRIT [200009532] Machine Id 08WEA84025 - GEN (S/N 72802187368)

Component

Coolant

CONVENTIONAL COOLANT (--- LTR)





DIAGNOSIS

Recommendation

The fluid is suitable for further service.

Corrosion

All metal levels are normal indicating no corrosion in the cooling system.

Contaminants

There is no indication of any contamination in the coolant.


Coolant Condition

Glycol and nitrite levels are acceptable. The pH level of this fluid is within the acceptable limits.


SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		NX015533	NX004817	
Sample Date		Client Info		11 Mar 2024	28 Apr 2022	
Machine Age	hrs	Client Info		60549	0	
Oil Age	hrs	Client Info		0	0	
Oil Changed		Client Info		N/A	N/A	
Sample Status				NORMAL	SEVERE	
PHYSICAL TEST R	ESULTS	method	limit/base	current	history1	history2
Glycol Type		FT-IR				
Specific Gravity		*ASTM D1298		1.076	1.073	
рН	Scale 0-14	ASTM D1287		8.51	9.05	
Nitrites	ppm	AP-053:2009		636	300	
Reserve Alkalinity	Scale 0-20	*ASTM D1121				
Percentage Glycol	%	ASTM D3321		56.4	54.7	
Freezing Point	°F	ASTM D3321		-50	-45	
Total Dissolved Solids				286.0	213.0	
Carboxylate				n/a	n/a	
CORROSION INH	IBITORS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D6130		17	35	
Phosphorus	ppm	ASTM D6130		1017	489	
Boron	ppm	ASTM D6130		192	226	
Molybdenum	ppm	ASTM D6130		134	597	
CORROSION		method	limit/base	current	history1	history2
Iron	ppm	ASTM D6130	>15	6	278	
Aluminum	ppm	ASTM D6130	>10	1	4	
Copper	ppm	ASTM D6130	>10	1	<1	
Lead	ppm	ASTM D6130	>10	<1	<1	
Tin	ppm	ASTM D6130	>10	0	0	
Zinc	ppm	ASTM D6130		0	17	
CONTAMINANTS		method	limit/base	current	history1	history2
Chlorine	ppm	ASTM D6130		22	0	
CARRIER SALTS		method	limit/base	current	history1	history2
Sodium	ppm	ASTM D6130		506	684	
Potassium	ppm	ASTM D6130		3165	1299	
SCALE POTENTI	AL	method	limit/base	current	history1	history2
Calcium	ppm	ASTM D6130		<1	0	
Magnesium	ppm	ASTM D6130		0	1	




COOLANT REPORT













Laboratory Sample No. Unique Number : 10937442

Lab Number : 06123291

: NX015533

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received

: 19 Mar 2024 **Tested** : 20 Mar 2024 Diagnosed : 22 Mar 2024 - Jonathan Hester

NORDEX USA - Chicago 300 SOUTH WACKER DRIVE, SUITE 1500

CHICAGO, IL US 60606

Test Package : COOL- (Additional Tests: BoilingPoint, COOL, GlycolType, ICP) To discuss this sample report, contact Customer Service at 1-800-237-1369.

Contact: DEVIN LINEHAN DLinehan@nordex-online.com

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) T: (312)386-4124 F: (312)386-7102

Contact/Location: DEVIN LINEHAN - NORDEX