


OIL ANALYSIS REPORT



NORMAL



[] WC-9800C-0106-5 Chiller #6

Component Chiller

YORK TYPE K (--- GAL)

Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Ma	r2023	Aug 2023 Mar 20	124	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0836544	WC0836533	WC0784771
Sample Date		Client Info		18 Mar 2024	13 Aug 2023	28 Mar 2023
Machine Age	hrs	Client Info		27563	26470	25455
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>8	0	<1	0
Chromium	ppm	ASTM D5185m	>2	0	0	0
Nickel	ppm	ASTM D5185m		0	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>3	0	0	0
Lead	ppm	ASTM D5185m	>2	0	0	0
Copper	ppm	ASTM D5185m	>8	0	<1	0
Tin	ppm	ASTM D5185m	>4	0	<1	<1
Vanadium	ppm	ASTM D5185m		0	<1	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	0
Barium	ppm	ASTM D5185m	0	0	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m	0	0	0	<1
Magnesium	ppm	ASTM D5185m	0	0	4	0
Calcium	ppm	ASTM D5185m	0	0	0	0
Phosphorus	ppm	ASTM D5185m	5	0	13	4
Zinc	ppm	ASTM D5185m	0	0	0	0
Sulfur	ppm	ASTM D5185m	10	0	11	0
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	6	8	7
Sodium	ppm	ASTM D5185m		0	0	0
Potassium	ppm	ASTM D5185m	>20	0	1	1
Water	%	ASTM D6304	>0.03	0.019	0.053	0.038
ppm Water	ppm	ASTM D6304	>300	199	532.6	383.2
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
	1/011:	4.0T1.4.D.00:-				

0.013

mg KOH/g ASTM D8045 0.03


Acid Number (AN)

0.014


0.015



OIL ANALYSIS REPORT



1200 -	Water (KF)		
1000-	Severe		
_ 800∙			i
Water (ppm)		<u> </u>	
[™] 400.	Abnormal		÷
200-			~
0			- + 5
	Mar28/23	Aug 13/23	Mar18/24
	<	< <	_



VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.03	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	TIEC	method	limit/base	ourrent	hiotony1	hiotory?
FLUID PROPER	IIES	method				history2

T LOID I HOI LITTILO							
Visc @ 40°C	cSt	ASTM D445	32.0	28.9	29.7	32.1	


Color

SAMPLE IMAGES













Certificate L2367

Laboratory Sample No. Lab Number : 06123735 Unique Number: 10937886

: WC0836544

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received

Tested Diagnosed

: 20 Mar 2024 : 21 Mar 2024

: 25 Mar 2024 - Jonathan Hester

Chugach Consolidated Solutions - NSA 10840 Guilford Road, Suites 406-407

Annapolis Junction, MD

US 20701 Contact: Susan Nord

susan.nord@chugachgov.com T: (301)688-6363

Test Package : PLANT To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: (443)479-5666