


OIL ANALYSIS REPORT

ULTRA FG [SVO-059945 OIL-46572] Machine Id INGERSOLL RAND VL1381U14073 - TERMINAL RAILROAD

Component

Compressor



DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

Waar

All component wear rates are normal.

Contamination

There is no indication of any contamination in the


Fluid Condition

The oil viscosity is higher than normal. The AN level is acceptable for this fluid.


SAMPLE INFORM	NOITAN	method	limit/base	current	history1	history2
Sample Number		Client Info		UCH06123792		
Sample Date		Client Info		08 Mar 2024		
Machine Age	hrs	Client Info		49981		
Oil Age	hrs	Client Info		4881		
Oil Changed		Client Info		Not Changd		
Sample Status				ATTENTION		
CONTAMINATION	١	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m		0		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>25	0		
Lead	ppm	ASTM D5185m	>25	0		
Copper	ppm	ASTM D5185m	>50	0		
Tin	ppm	ASTM D5185m	>15	0		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		16		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m		0		
Calcium	ppm	ASTM D5185m		81		
Phosphorus	ppm	ASTM D5185m		192		
Zinc	ppm	ASTM D5185m		3		
Sulfur	ppm	ASTM D5185m		496		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0		
Sodium	ppm	ASTM D5185m		27		
Potassium	ppm	ASTM D5185m	>20	2		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.33		




OIL ANALYSIS REPORT




VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE		
Yellow Metal	scalar	*Visual	NONE	NONE		
Precipitate	scalar	*Visual	NONE	NONE		
Silt	scalar	*Visual	NONE	NONE		
Debris	scalar	*Visual	NONE	NONE		
Sand/Dirt	scalar	*Visual	NONE	NONE		
Appearance	scalar	*Visual	NORML	NORML		
Odor	scalar	*Visual	NORML	NORML		
Emulsified Water	scalar	*Visual	>0.1	NEG		
Free Water	scalar	*Visual		NEG		
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46.0	59.86		
SAMPLE IMAGES	5	method	limit/base	current	history1	history2
Color					no image	no image
Bottom					no image	no image
GRAPHS						













Certificate L2367

Laboratory

Sample No.

Lab Number : 06123792

Unique Number : 10937943 Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : UCH06123792 Received **Tested**

Diagnosed

: 20 Mar 2024 : 27 Mar 2024 : 27 Mar 2024 - Jonathan Hester JOHN HENRY FOSTER COMPANY

4700 LEBOURGET STREET SAINT LOUIS, MO

US 63134 Contact: RACHEL VON HATTEN

rvonhatten@jhf.com

T: (314)593-1267 F: (314)874-0965

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)