


## **OIL ANALYSIS REPORT**

# SMART OIL Machine Id HERTZ VD011216 - CALHOUN PLASTIC & CHEMICALS

Component

Compressor

SMARTOIL 6000 (10 GAL)





#### DIAGNOSIS

#### Recommendation

Resample at the next service interval to monitor.

#### Moor

All component wear rates are normal.

#### Contamination

There is no indication of any contamination in the oil.


### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UHK06123826	UHK06097084	UHK0000092
Sample Date		Client Info		01 Mar 2024	14 Dec 2023	28 Dec 2022
Machine Age	hrs	Client Info		4777	4009	0
Oil Age	hrs	Client Info		0	4009	0
Oil Changed		Client Info		Not Changd	Not Changd	Changed
Sample Status				NORMAL	NORMAL	ATTENTION
CONTAMINATION	١	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG	NEG	NEG
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	<1
Chromium	ppm	ASTM D5185m	>10	0	<1	0
Nickel	ppm	ASTM D5185m		0	0	<1
Titanium	ppm	ASTM D5185m		0	<1	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>25	0	<1	<1
Lead	ppm	ASTM D5185m	>25	0	0	0
Copper	ppm	ASTM D5185m	>50	0	<1	<1
Tin	ppm	ASTM D5185m	>15	0	<1	<1
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	1
Molybdenum	ppm	ASTM D5185m		0	<1	0
Manganese	ppm	ASTM D5185m		0	0	<1
Magnesium	ppm	ASTM D5185m		0	0	2
Calcium	ppm	ASTM D5185m	20	0	<1	1
Phosphorus	ppm	ASTM D5185m		440	403	33
Zinc	ppm	ASTM D5185m		0	0	11
Sulfur	ppm	ASTM D5185m		512	429	133
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	1	1
Sodium	ppm	ASTM D5185m		0	0	1
Potassium	ppm	ASTM D5185m	>20	0	<1	0
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.28	0.26	0.13



## **OIL ANALYSIS REPORT**



Viscosity	@ 40°C	:		
Abnormal				
52				
50				
48 - Base		-	The state of the s	
46 Base				
44				
42 - Abnormal				
52 01	22 -	22 -	23 -	
Jun2/	Sep12/2	)ec28/22	)ec14/	
-	Š	ă	ă	

VISUAL		method				history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	LIGHT	NONE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
<b>Emulsified Water</b>	scalar	*Visual	>0.1	NEG	NEG	0.2%
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	TES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	49.9	49.7	46.4

SAMPLE IMAGES


Color


**Bottom** 





















Certificate L2367

Laboratory Sample No. Lab Number : 06123826

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : UHK06123826

Received **Tested** Unique Number : 10937977 Diagnosed Test Package : IND 2

: 20 Mar 2024 : 21 Mar 2024 : 22 Mar 2024 - Don Baldridge

ATLANTA AIR COMPRESSOR - HERTZ 123 MERCHANTS PARK DR

HOSCHTON, GA US 30548

Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:

F: