


OIL ANALYSIS REPORT







8829285 (S/N 1299)

Component

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

There is too much water present in this sample to perform a particle count. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition.

Wear

All component wear rates are normal.

Contamination

There is a light concentration of water present in the oil. Excessive free water present.

Fluid Condition

The AN level is acceptable for this fluid.

			Nov2023	Mar2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA014980	KCPA011360	
Sample Date		Client Info		12 Mar 2024	21 Nov 2023	
Machine Age	hrs	Client Info		5469	4161	
Oil Age	hrs	Client Info		0	0	
Oil Changed		Client Info		Not Changd	N/A	
Sample Status				ABNORMAL	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	1	<1	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	<1	<1	
Lead	ppm	ASTM D5185m	>10	0	0	
Copper	ppm	ASTM D5185m	>50	4	2	
Tin	ppm	ASTM D5185m	>10	0	0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES	le le	method	limit/base	current	history1	history2
						matoryz
Boron	ppm	ASTM D5185m	0	0	0	
Barium	ppm	ASTM D5185m	90	0	0	
Molybdenum	ppm	ASTM D5185m	0	0	0	
Manganese	ppm	ASTM D5185m	100	0	0	
Magnesium	ppm	ASTM D5185m	100	0	0	
Calcium	ppm	ASTM D5185m	0	1	<1	
Phosphorus	ppm	ASTM D5185m	0	36	43	
Zinc	ppm	ASTM D5185m	0	34	37	
Sulfur	ppm	ASTM D5185m	23500	4991	1199	
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	8	3	
Sodium	ppm	ASTM D5185m		1	2	
Potassium	ppm	ASTM D5185m	>20	0	2	
Water	%	ASTM D6304	>0.05	<u> </u>	△ 0.071	
ppm Water	ppm	ASTM D6304	>500	<u> </u>	△ 710	
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647			9013	
Particles >6μm		ASTM D7647	>1300		981	
Particles >14μm		ASTM D7647	>80		18	
Particles >21µm		ASTM D7647	>20		3	
Particles >38µm		ASTM D7647	>4		0	
Particles >71µm		ASTM D7647	>3		0	
Oil Cleanliness		ISO 4406 (c)	>/17/13		20/17/11	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
	ma 1/011/a	ACTM DODAE	4.0	0.25	0.24	

Acid Number (AN)


mg KOH/g ASTM D8045 1.0

0.34

0.35



OIL ANALYSIS REPORT







Certificate L2367

Laboratory Sample No.

Lab Number : 06124318 Unique Number: 10938469

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 : KCPA014980

Received **Tested** Diagnosed

: 23 Mar 2024 - Don Baldridge Test Package: IND 2 (Additional Tests: KF, PrtCount) To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

: 20 Mar 2024

: 23 Mar 2024

US 95377 Contact: PHIL CERVANTES

phil.cervantes@basalite.com

11888 W LINNE RD

TRACY, CA

T: F:

Contact/Location: PHIL CERVANTES - PACTRA