


# **PROBLEM SUMMARY**

#### Area WH-100 Machine Id B25970 - STORK COOKER GEARBOX #7 (2ND ON CHILL SECTION) Component Gearbox Fluid

# PETRO CANADA ENDURATEX WG 680 (--- GAL)

# COMPONENT CONDITION SUMMARY



### RECOMMENDATION

Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

PROBLEMATIC TEST RESULTS								
Sample Status		ę	SEVERE	ATTENTION	ABNORMAL			
Particles >4µm	ASTM D7647	>10000	402935	18963				
Particles >6µm	ASTM D7647	>2500	125965	3188				
Particles >14µm	ASTM D7647	>320	64 764	92				
Oil Cleanliness	ISO 4406 (c)	>20/18/15	<b>26/24/17</b>	21/19/14				


Customer Id: HORAUS Sample No.: WC0894853 Lab Number: 06124882 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data: Wes Davis +1 905-569-8600 x223 wesd@wearcheck.ca

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com



RECOMMENDED ACTIONS						
Action	Status	Date	Done By	Description		
Change Filter			?	We recommend you service the filters on this component.		
Resample			?	Resample in 30-45 days to monitor this situation.		
Information Required			?	NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.		
Check Breathers			?	The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather.		
Check Seals			?	Check seals and/or filters for points of contaminant entry.		

#### HISTORICAL DIAGNOSIS

#### 10 Jan 2024 Diag: Wes Davis

ISO

We recommend you service the filters on this component. Resample at the next service interval to monitor. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.All component wear rates are normal. There is a light amount of silt (particulates < 14 microns in size) present in the oil. The water content is negligible. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.



#### \_\_\_\_

### 29 Nov 2023 Diag: Jonathan Hester

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. There is a moderate amount of visible silt present in the sample. The oil viscosity is higher than normal. The AN level is acceptable for this fluid.



#### ISO



### 25 Jul 2023 Diag: Don Baldridge

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.All component wear rates are normal. There is a high amount of particulates present in the oil. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.





# **OIL ANALYSIS REPORT**

SAMPLE INFORMATION

#### Area WH-100 Machine Id B25970 - STORK COOKER GEARBOX #7 (2ND ON CHILL SECTION) Component Gearbox Fluid

PETRO CANADA ENDURATEX WG 680 (--- GAL)

#### DIAGNOSIS

## Recommendation

Check seals and/or filters for points of contaminant entry. The air breather requires service. If unrated, we recommend that you replace with a suitable micron rated and/or desiccant air breather. If rated, we recommend that you service/replace the breather. We recommend you service the filters on this component. Resample in 30-45 days to monitor this situation. NOTE: Please provide information regarding reservoir capacity, filter type and micron rating with next sample.

### Wear

All component wear rates are normal.

### Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil. The system cleanliness code is much higher than the acceptable limit for the target ISO 4406 cleanliness code.

#### Fluid Condition

The AN level is acceptable for this fluid. The oil is still serviceable provided that the contaminant(s) can be reduced to acceptable levels.




SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0894853	WC0880596	WC0856021
Sample Date		Client Info		06 Mar 2024	10 Jan 2024	29 Nov 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				SEVERE	ATTENTION	ABNORMAL
CONTAMINATIO	N	method	limit/base	current	history1	history2
Water		WC Method		NEG	NEG	NEG
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>200	14	8	10
Chromium	ppm	ASTM D5185m		<1	<1	0
Nickel	ppm	ASTM D5185m		0	0	<1
Titanium	ppm	ASTM D5185m	210	0	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>25	0	2	0
Lead	ppm	ASTM D5185m		0	0	0
Copper	ppm	ASTM D5185m		8	5	9
Tin		ASTM D5185m		。 <1	0	0
Vanadium	ppm	ASTM D5185m	>20	< 1	0	0
Cadmium	ppm	ASTM D5185m ASTM D5185m		0	0	0
	ppm	IIICOLCO INLOW		U	0	-
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	1	0	0	0
Barium	ppm	ASTM D5185m	1	0	3	0
Molybdenum	ppm	ASTM D5185m	1	<1	0	0
Manganese	ppm	ASTM D5185m	1	<1	0	<1
Magnesium	ppm	ASTM D5185m	1	0	0	0
Calcium	ppm	ASTM D5185m	1	0	<1	2
Phosphorus	ppm	ASTM D5185m	1	0	46	<1
Zinc	ppm	ASTM D5185m	1	7	0	4
Sulfur	ppm	ASTM D5185m	3114	3063	3053	2437
CONTAMINANTS	6	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>50	2	1	<1
Sodium	ppm	ASTM D5185m		<1	0	2
Potassium	ppm	ASTM D5185m	>20	0	<1	0
FLUID CLEANLIN	NESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	<b>4</b> 02935	18963	
Particles >6µm		ASTM D7647	>2500	<b>125965</b>	3188	
Particles >14µm		ASTM D7647	>320	<u> </u>	92	
Particles >21µm		ASTM D7647	>80	81	18	
Particles >38µm		ASTM D7647	>20	3	1	
Particles >71µm		ASTM D7647	>4	1	0	
Oil Cleanliness		ISO 4406 (c)	>20/18/15	<b>26/24/17</b>	21/19/14	
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.43	1.25	0.87	1.25
. ,	5 5					


Report Id: HORAUS [WUSCAR] 06124882 (Generated: 03/22/2024 07:36:55) Rev: 1


Contact/Location: JIM COWELL - HORAUS



# **OIL ANALYSIS REPORT**







Jan 25/22

500

400

300


200

May21/1

Jan 1

VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	A MODER
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.2	NEG	0.2%	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	676.7	733	708	▲ 792.1
SAMPLE IMAGES	6	method	limit/base	current	history1	history2
Color					•	
					102	

Bottom



Report Id: HORAUS [WUSCAR] 06124882 (Generated: 03/22/2024 07:36:55) Rev: 1

Certificate L2367

Contact/Location: JIM COWELL - HORAUS