


# **OIL ANALYSIS REPORT**

# OMNILUBE 546 Machine Id QUINCY BU0908070094 - HP HOOD

Component

Compressor





#### DIAGNOSIS

#### Recommendation

Resample at the next service interval to monitor.

#### Wear

All component wear rates are normal.

#### Contamination

There is no indication of any contamination in the oil.

### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

		Dec2019	Julž021	Feb 2022 Sep 2022	Mar2024	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UCH06125001	UCH05655351	UCH05464829
Sample Date		Client Info		12 Mar 2024	23 Sep 2022	04 Feb 2022
Machine Age	hrs	Client Info		51639	0	38307
Oil Age	hrs	Client Info		0	0	1
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	NORMAL
CONTAMINATION	V	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG	NEG	NEG
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	0
Chromium	ppm	ASTM D5185m	>10	<1	0	0
Nickel	ppm	ASTM D5185m		0	0	0
Titanium	ppm	ASTM D5185m		<1	0	0
Silver	ppm	ASTM D5185m		0	0	<1
Aluminum	ppm	ASTM D5185m	>25	3	0	3
Lead	ppm	ASTM D5185m	>25	0	0	<1
Copper	ppm	ASTM D5185m	>50	<1	0	0
Tin	ppm	ASTM D5185m	>15	<1	0	0
Antimony	ppm	ASTM D5185m				<1
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	<1
Barium	ppm	ASTM D5185m	0	1	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m	0	0	0	0
Magnesium	ppm	ASTM D5185m	1.2	<1	0	0
Calcium	ppm	ASTM D5185m	0	4	0	<1
Phosphorus	ppm	ASTM D5185m	295	274	327	431
Zinc	ppm	ASTM D5185m	0	4	0	0
Sulfur	ppm	ASTM D5185m	253	1109	443	279
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	1	<1
Sodium	ppm	ASTM D5185m		0	<1	0
Potassium	ppm	ASTM D5185m	>20	2	0	0
FLUID DEGRADA	TION	method	limit/base	current	history1	history2

Acid Number (AN)

mg KOH/g ASTM D8045 0.252


0.07

0.31

0.28




# **OIL ANALYSIS REPORT**





			65	2
	y @ 40°C			
54 Abnormal				
50				
(0 48 - Base (0 46 - Base 3 44 - Base				
8 44-	and the same of th			
42 - Abnormal				
40				
	4/21-	727	/22	/24
Dec12/19	Jul14/2	Feb 4/22	Sep23/22	Mar12/24
_				_


VISUAL		method				history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	VLITE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
<b>Emulsified Water</b>	scalar	*Visual	>0.1	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	TES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	47.16	44.9	46.0	45.3
SAMDLE IMAGES						


Color **Bottom** 















Certificate L2367

Laboratory Sample No.

Test Package : IND 2

: UCH06125001 Lab Number : 06125001 Unique Number : 10939152

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received **Tested** 

: 21 Mar 2024 : 22 Mar 2024

Diagnosed : 24 Mar 2024 - Don Baldridge

## **CUMMINS-WAGNER CO INC**

175 Edgemoor Rd WILMINGTON, DE US 19809

Contact: Natalie Gagliano

NGagliano@cummins-wagner.com T: (833)568-5450

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)