




# OIL ANALYSIS REPORT

Sample Rating Trend

**NORMAL**



Machine Id  
**BULK ZOK - SHELL MYSELLA SAE 40**  
 Component  
**New (Unused) Oil**  
 Fluid  
**SHELL SHELL MYSELLA S3 N 40 (600 GAL)**

## DIAGNOSIS

### Recommendation

This is a baseline read-out on the submitted sample.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			<b>WC0775208</b>	WC0675551	WC0675541
Sample Date	Client Info			<b>19 Mar 2024</b>	03 Jan 2024	20 Nov 2023
Machine Age	hrs	Client Info		<b>1</b>	77881	77881
Oil Age	hrs	Client Info		<b>1</b>	1	100
Oil Changed	Client Info			<b>N/A</b>	N/A	N/A
Sample Status				<b>NORMAL</b>	NORMAL	NORMAL

CONTAMINATION		method	limit/base	current	history1	history2
Water	WC Method			<b>NEG</b>	NEG	NEG

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>5	<b>0</b>	<1	0
Chromium	ppm	ASTM D5185m	>5	<b>0</b>	0	0
Nickel	ppm	ASTM D5185m	>5	<b>0</b>	0	<1
Titanium	ppm	ASTM D5185m		<b>0</b>	0	0
Silver	ppm	ASTM D5185m	>5	<b>&lt;1</b>	0	0
Aluminum	ppm	ASTM D5185m	>5	<b>2</b>	2	2
Lead	ppm	ASTM D5185m	>5	<b>0</b>	0	0
Copper	ppm	ASTM D5185m	>5	<b>0</b>	<1	0
Tin	ppm	ASTM D5185m	>5	<b>0</b>	0	<1
Vanadium	ppm	ASTM D5185m		<b>&lt;1</b>	<1	0
Cadmium	ppm	ASTM D5185m		<b>0</b>	0	0





ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		<b>&lt;1</b>	4	<1
Barium	ppm	ASTM D5185m		<b>0</b>	0	0
Molybdenum	ppm	ASTM D5185m		<b>&lt;1</b>	2	<1
Manganese	ppm	ASTM D5185m		<b>0</b>	0	0
Magnesium	ppm	ASTM D5185m		<b>0</b>	25	10
Calcium	ppm	ASTM D5185m		<b>1324</b>	1423	1374
Phosphorus	ppm	ASTM D5185m		<b>222</b>	300	295
Zinc	ppm	ASTM D5185m		<b>310</b>	374	336
Sulfur	ppm	ASTM D5185m		<b>2850</b>	2832	2869

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	<b>6</b>	6	5
Sodium	ppm	ASTM D5185m		<b>&lt;1</b>	<1	1
Potassium	ppm	ASTM D5185m	>20	<b>0</b>	0	<1

INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844		<b>---</b>	---	---
Nitration	Abs/cm	*ASTM D7624		<b>---</b>	---	---
Sulfation	Abs/.1mm	*ASTM D7415		<b>---</b>	---	---

FLUID DEGRADATION		method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414		<b>---</b>	---	---
Acid Number (AN)	mg KOH/g	ASTM D8045		<b>0.19</b>	0.73	0.514
Base Number (BN)	mg KOH/g	ASTM D2896	5	<b>4.78</b>	4.76	4.91


# OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	<b>NONE</b>	NONE
Yellow Metal	scalar	*Visual	NONE	<b>NONE</b>	NONE
Precipitate	scalar	*Visual	NONE	<b>NONE</b>	NONE
Silt	scalar	*Visual	NONE	<b>NONE</b>	NONE
Debris	scalar	*Visual	NONE	<b>LIGHT</b>	NONE
Sand/Dirt	scalar	*Visual	NONE	<b>NONE</b>	NONE
Appearance	scalar	*Visual	NORML	<b>NORML</b>	NORML
Odor	scalar	*Visual	NORML	<b>NORML</b>	NORML
Emulsified Water	scalar	*Visual		<b>NEG</b>	NEG
Free Water	scalar	*Visual		<b>NEG</b>	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	135	<b>128.4</b>	128.1
Visc @ 100°C	cSt	ASTM D445	13.5	<b>13.57</b>	13.43
Viscosity Index (VI)	Scale	ASTM D2270	94	<b>100</b>	99

### SAMPLE IMAGES



### GRAPHS



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC0775208 **Received** : 21 Mar 2024  
**Lab Number** : **06125283** **Tested** : 26 Mar 2024  
**Unique Number** : 10939434 **Diagnosed** : 26 Mar 2024 - Jonathan Hester  
**Test Package** : MOB 2 ( Additional Tests: FT-IR, ICP-NewOil, KV100, PrtCount, TBN, VI )

**EDL NA Recips-Zook**  
 Zook Powerstation, 388 E. Main Street  
 Leola, PA  
 US 17540-1925  
 Contact: Kevin Johnson  
 kevin.johnson@edlenergy.com  
 T:  
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)