


OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



STARLINE SL-5104 6113

Component

Hydraulic System

{not provided} (--- GAL)

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Aug	2023	Nov2023 Mar20	24	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		PH0002356	PH0002401	PH0001997
Sample Date		Client Info		21 Mar 2024	14 Nov 2023	28 Aug 2023
Machine Age	hrs	Client Info		0	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>20	0	0	<1
Chromium	ppm	ASTM D5185m	>20	0	0	6
Nickel	ppm	ASTM D5185m	>20	0	0	<1
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>20	0	0	<1
Lead	ppm	ASTM D5185m	>20	<1	0	<1
Copper	ppm	ASTM D5185m	>20	0	0	<1
Tin	ppm	ASTM D5185m	>20	<1	1	0
Vanadium	ppm	ASTM D5185m		<1	0	<1
Cadmium	ppm	ASTM D5185m		<1	<1	<1
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m		0	0	2
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	<1	0
Magnesium	ppm	ASTM D5185m		0	<1	<1
Calcium	ppm	ASTM D5185m		<1	4	6
Phosphorus	ppm	ASTM D5185m		28038	30304	12328
Zinc	ppm	ASTM D5185m		0	0	3
Sulfur	ppm	ASTM D5185m		2185	1783	2100
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	<1	<1	2
Sodium	ppm	ASTM D5185m		2	2	4
Potassium	ppm	ASTM D5185m		15	13	20
Water	%	ASTM D6304	>0.05	NEG	NEG	NEG
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	741	389	378
Particles >6µm		ASTM D7647	>2500	220	83	125
Particles >14μm		ASTM D7647	>320	38	5	32
Particles >21µm		ASTM D7647	>80	15	1	12
Particles >38μm		ASTM D7647	>20	0	0	1
Particles >71μm		ASTM D7647	>4	0	0	0
Oil Cleanliness		ISO 4406 (c)	>20/18/15	17/15/12	16/14/10	16/14/12
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
	1/011/	4 OT1 4 D 00 4 F				

Acid Number (AN)

mg KOH/g ASTM D8045


0.038

0.046

0.041



OIL ANALYSIS REPORT







Laboratory Sample No.

: WearCheck USA - 501 Madison Ave., Cary, NC 27513

: PH0002356 Lab Number : 06125311

Received **Tested** Unique Number: 10939462

Diagnosed Test Package: PLANT (Additional Tests: KF, PrtFilter)

: 21 Mar 2024 : 27 Mar 2024

: 27 Mar 2024 - Jonathan Hester

NORDAM 6911 WHILPOOL DR TULSA, OK US 74117

T: (918)401-5219

Contact: KURT BODENHAMER kbodenhamer@nordam.com

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: