


OIL ANALYSIS REPORT



KAESER SM 15 6862536 (S/N 1008)

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

Elemental level of silicon (Si) above normal. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

			Nov2021	Mar2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA014922	KCP39880	
Sample Date		Client Info		08 Mar 2024	02 Nov 2021	
Machine Age	hrs	Client Info		2895	1884	
Oil Age	hrs	Client Info		1000	1884	
Oil Changed	1110	Client Info		Changed	Changed	
Sample Status				ABNORMAL	ABNORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	<1	
Chromium	ppm	ASTM D5185m	>10	0	0	
Nickel	ppm	ASTM D5185m	>3	0	0	
Titanium	ppm	ASTM D5185m	>3	0	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	0	<1	
Lead	ppm	ASTM D5185m	>10	0	0	
Copper	ppm	ASTM D5185m	>50	2	4	
Tin	ppm	ASTM D5185m	>10	0	0	
Antimony	ppm	ASTM D5185m	710		0	
Vanadium	ppm	ASTM D5185m		0	0	
Cadmium	ppm	ASTM D5185m		0	0	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	<1	
Barium	ppm	ASTM D5185m	90	0	0	
Molybdenum	ppm	ASTM D5185m	0	0	0	
Manganese	ppm	ASTM D5185m	U	<1	<1	
Magnesium	ppm	ASTM D5185m	100	29	29	
Calcium	ppm	ASTM D5185m	0	0	0	
Phosphorus	ppm	ASTM D5185m	0	0	1	
Zinc	ppm	ASTM D5185m	0	13	7	
Sulfur	ppm	ASTM D5185m	23500	21018	15519	
CONTAMINANTS		method	limit/base			hioton/2
				current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<u>^</u> 29	0	
Sodium	ppm	ASTM D5185m		10	9	
Potassium	ppm	ASTM D5185m	>20	0	0	
Water	%	ASTM D6304	>0.05	0.033	0.020	
ppm Water	ppm	ASTM D6304	>500	334	204.3	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		1012	26054	
Particles >6µm		ASTM D7647	>1300	391	<u>▲</u> 11775	
Particles >14μm		ASTM D7647	>80	40	<u>▲</u> 565	
Particles >21µm		ASTM D7647	>20	11	△ 97	
Particles >38μm		ASTM D7647	>4	1	3	
Particles >71μm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	17/16/12	<u></u>	
FLUID DEGRADA	TION	method	limit/base	current	history1	history2



OIL ANALYSIS REPORT







Certificate L2367

Sample No. Lab Number

: KCPA014922 : 06125664

Tested Unique Number: 10939815 Diagnosed

: 25 Mar 2024

: 25 Mar 2024 - Don Baldridge

Test Package: IND 2 (Additional Tests: KF, PrtCount)

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

1210 RICHVALE HWY

OROVILLE, CA US 95965

Contact: Service Manager

T: F: