


# **PROBLEM SUMMARY**


<sup>Machine Id</sup> **2519476 (S/N 1177)** 


Component Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)



# COMPONENT CONDITION SUMMARY





## **RECOMMENDATION**

We advise that you check all areas where dirt can enter the system. Oil and filter change at the time of sampling has been noted. We recommend an early resample to monitor this condition.

PROBLEMATIC TEST RESULTS										
Sample Status				SEVERE	SEVERE	SEVERE				
Silicon	ppm	ASTM D5185m	>25	<b>▲</b> 51	<b>4</b> 95	<b>▲</b> 112				
Particles >6µm		ASTM D7647	>1300	<b>13210</b>		<b>▲</b> 3692				
Particles >14µm		ASTM D7647	>80	<b>2570</b>		<u>\$\times\$ 250</u>				
Particles >21µm		ASTM D7647	>20	<b>1039</b>		<b>△</b> 69				
Particles >38µm		ASTM D7647	>4	<b>△</b> 65		3				
Oil Cleanliness		ISO 4406 (c)	>/17/13	<b>22/21/19</b>		<b>1</b> 9/15				

**Customer Id: CALREN** Sample No.: KCPA014954 Lab Number: 06125665 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:

Don Baldridge +1 don.b505@comcast.net

To change component or sample information: Customer Service +1 1-800-237-1369 customerservice@wearcheck.com

RECOMMENDED ACTIONS							
Action	Status	Date	Done By	Description			
Change Fluid			?	Oil and filter change at the time of sampling has been noted.			
Change Filter			?	Oil and filter change at the time of sampling has been noted.			
Resample			?	We recommend an early resample to monitor this condition.			
Check Dirt Access			?	We advise that you check all areas where dirt can enter the system.			

# HISTORICAL DIAGNOSIS

## 15 Jun 2023 Diag: Angela Borella

The filter change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.All component wear rates are normal. Elemental level of silicon (Si) above normal indicating ingress of seal material. Moderate concentration of visible dirt/debris present in the oil. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.



## 14 Mar 2022 Diag: Don Baldridge

DIRT



We advise that you check all areas where dirt can enter the system. Oil and filter change at the time of sampling has been noted. We recommend an early resample to monitor this condition. All component wear rates are normal. There is a high amount of particulates present in the oil. Elemental level of silicon (Si) above normal. The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.



### 14 Jul 2021 Diag: Jonathan Hester

DIRT




Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample. All component wear rates are normal. Elemental level of silicon (Si) above normal indicating ingress of seal material. Moderate concentration of visible dirt/debris present in the oil. The oil viscosity is higher than normal. The AN level is acceptable for this fluid.





# **OIL ANALYSIS REPORT**

Sample Rating Trend



# 2519476 (S/N 1177)

Component

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

## DIAGNOSIS

### Recommendation

We advise that you check all areas where dirt can enter the system. Oil and filter change at the time of sampling has been noted. We recommend an early resample to monitor this condition.

### Wear

All component wear rates are normal.

### ▲ Contamination

There is a high amount of particulates present in the oil. Elemental level of silicon (Si) above normal.

#### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

		Dec2020	Jul2021	Mar2022 Jun2023	Mar2024	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA014954	KCPA002457	KCP41072
Sample Date		Client Info		14 Mar 2024	15 Jun 2023	14 Mar 2022
Machine Age	hrs	Client Info		70307	65687	59545
Oil Age	hrs	Client Info		4620	0	0
Oil Changed		Client Info		Changed	N/A	Changed
Sample Status				SEVERE	SEVERE	SEVERE
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	0
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	<1	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	<1	0	<1
Aluminum	ppm	ASTM D5185m	>10	0	0	0
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	11	23	19
Tin	ppm	ASTM D5185m	>10	0	0	0
Antimony	ppm	ASTM D5185m				
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	0
Barium	ppm	ASTM D5185m	90	0	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m	100	0	2	0
Calcium	ppm	ASTM D5185m	0	0	0	0
Phosphorus	ppm	ASTM D5185m	0	0	0	5
Zinc	ppm	ASTM D5185m	0	0	0	0
Sulfur	ppm	ASTM D5185m	23500	18468	20818	16808
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<b>▲</b> 51	<b>4</b> 95	<b>▲</b> 112
Sodium	ppm	ASTM D5185m		2	0	0
Potassium	ppm	ASTM D5185m	>20	0	<1	0
Water	%	ASTM D6304	>0.05	0.003	0.004	0.003
ppm Water	ppm	ASTM D6304	>500	27	46.8	28.9
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		32603		17853
Particles >6µm		ASTM D7647	>1300	<u> </u>		▲ 3692
Particles >14μm		ASTM D7647	>80	<u>^</u> 2570		<u>^</u> 250
Particles >21µm		ASTM D7647	>20	<u> </u>		<b>△</b> 69
Particles >38μm		ASTM D7647	>4	<u>^</u> 65		3
Particles >71µm		ASTM D7647		2		0
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>22/21/19</u>		<u> </u>
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2

0.49

0.46



# **OIL ANALYSIS REPORT**

