




# OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Machine Id  
**1925120 (S/N 1486)**

Component  
**Compressor**

Fluid  
**KAESER SIGMA (OEM) M-460 (--- GAL)**

## DIAGNOSIS

### ▲ Recommendation

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### ▲ Contamination

There is a high amount of particulates present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>KCPA014965</b>	---	---
Sample Date	Client Info	<b>12 Feb 2024</b>	---	---
Machine Age	hrs Client Info	<b>93216</b>	---	---
Oil Age	hrs Client Info	<b>0</b>	---	---
Oil Changed	Client Info	<b>Changed</b>	---	---
Sample Status		<b>ABNORMAL</b>	---	---

## WEAR METALS

method	limit/base	current	history1	history2
Iron ppm	ASTM D5185m >50	<b>0</b>	---	---
Chromium ppm	ASTM D5185m >10	<b>0</b>	---	---
Nickel ppm	ASTM D5185m >3	<b>0</b>	---	---
Titanium ppm	ASTM D5185m >3	<b>0</b>	---	---
Silver ppm	ASTM D5185m >2	<b>0</b>	---	---
Aluminum ppm	ASTM D5185m >10	<b>0</b>	---	---
Lead ppm	ASTM D5185m >10	<b>0</b>	---	---
Copper ppm	ASTM D5185m >50	<b>0</b>	---	---
Tin ppm	ASTM D5185m >10	<b>0</b>	---	---
Vanadium ppm	ASTM D5185m	<b>0</b>	---	---
Cadmium ppm	ASTM D5185m	<b>0</b>	---	---

## ADDITIVES

method	limit/base	current	history1	history2
Boron ppm	ASTM D5185m 0	<b>0</b>	---	---
Barium ppm	ASTM D5185m 90	<b>86</b>	---	---
Molybdenum ppm	ASTM D5185m 0	<b>0</b>	---	---
Manganese ppm	ASTM D5185m	<b>0</b>	---	---
Magnesium ppm	ASTM D5185m 100	<b>89</b>	---	---
Calcium ppm	ASTM D5185m 0	<b>2</b>	---	---
Phosphorus ppm	ASTM D5185m 0	<b>0</b>	---	---
Zinc ppm	ASTM D5185m 0	<b>0</b>	---	---
Sulfur ppm	ASTM D5185m 23500	<b>21601</b>	---	---

## CONTAMINANTS

method	limit/base	current	history1	history2
Silicon ppm	ASTM D5185m >25	<b>0</b>	---	---
Sodium ppm	ASTM D5185m	<b>13</b>	---	---
Potassium ppm	ASTM D5185m >20	<b>&lt;1</b>	---	---
Water %	ASTM D6304 >0.05	<b>0.021</b>	---	---
ppm Water	ASTM D6304 >500	<b>217</b>	---	---






## FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	<b>15177</b>	---	---
Particles >6µm	ASTM D7647 >1300	▲ <b>5154</b>	---	---
Particles >14µm	ASTM D7647 >80	▲ <b>531</b>	---	---
Particles >21µm	ASTM D7647 >20	▲ <b>144</b>	---	---
Particles >38µm	ASTM D7647 >4	<b>4</b>	---	---
Particles >71µm	ASTM D7647 >3	<b>0</b>	---	---
Oil Cleanliness	ISO 4406 (c) >--/17/13	▲ <b>21/20/16</b>	---	---

## FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN) mg KOH/g	ASTM D8045 1.0	<b>0.40</b>	---	---

# OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2	
White Metal	scalar	*Visual	NONE	NONE	---	---
Yellow Metal	scalar	*Visual	NONE	NONE	---	---
Precipitate	scalar	*Visual	NONE	NONE	---	---
Silt	scalar	*Visual	NONE	NONE	---	---
Debris	scalar	*Visual	NONE	NONE	---	---
Sand/Dirt	scalar	*Visual	NONE	NONE	---	---
Appearance	scalar	*Visual	NORML	NORML	---	---
Odor	scalar	*Visual	NORML	NORML	---	---
Emulsified Water	scalar	*Visual	>0.05	NEG	---	---
Free Water	scalar	*Visual		NEG	---	---

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 40°C	cSt	ASTM D445	45	46.3	---	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------

Color				no image	no image
Bottom				no image	no image

## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : KCPA014965 **Received** : 21 Mar 2024  
**Lab Number** : 06125668 **Tested** : 25 Mar 2024  
**Unique Number** : 10939819 **Diagnosed** : 25 Mar 2024 - Don Baldrige  
**Test Package** : IND 2 ( Additional Tests: KF, PrtCount )

**CITY OF SACRAMENTO**  
 7501 COLLEGE TOWN DR  
 SACRAMENTO, CA  
 US 95826  
 Contact: SERVICE MANAGER  
 acontaxis@cityofsacramento.org  
 T:  
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)