




# OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id  
**KAESER SX 5 4467852 (S/N 1102)**

Component  
**Compressor**  
Fluid  
**KAESER SIGMA (OEM) M-460 (--- GAL)**

## DIAGNOSIS

### Recommendation

Oil and filter change at the time of sampling has been noted. No corrective action is recommended at this time. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is a high amount of particulates present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>KCPA013921</b>	KCPA007707	KCP54883
Sample Date	Client Info		<b>13 Mar 2024</b>	12 Oct 2023	27 Jan 2023
Machine Age	hrs	Client Info	<b>77047</b>	73377	73355
Oil Age	hrs	Client Info	<b>3670</b>	0	5038
Oil Changed	Client Info		<b>Changed</b>	N/A	Not Changd
Sample Status			<b>ABNORMAL</b>	NORMAL	ABNORMAL

## WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >50	<b>0</b>	0	<1
Chromium	ppm	ASTM D5185m >10	<b>0</b>	0	0
Nickel	ppm	ASTM D5185m >3	<b>0</b>	<1	0
Titanium	ppm	ASTM D5185m >3	<b>0</b>	0	0
Silver	ppm	ASTM D5185m >2	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m >10	<b>0</b>	0	<1
Lead	ppm	ASTM D5185m >10	<b>0</b>	0	0
Copper	ppm	ASTM D5185m >50	<b>&lt;1</b>	1	2
Tin	ppm	ASTM D5185m >10	<b>0</b>	<1	<1
Vanadium	ppm	ASTM D5185m	<b>0</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	0

## ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m 0	<b>0</b>	0	0
Barium	ppm	ASTM D5185m 90	<b>22</b>	0	3
Molybdenum	ppm	ASTM D5185m 0	<b>0</b>	0	0
Manganese	ppm	ASTM D5185m	<b>&lt;1</b>	<1	0
Magnesium	ppm	ASTM D5185m 100	<b>51</b>	30	34
Calcium	ppm	ASTM D5185m 0	<b>&lt;1</b>	1	0
Phosphorus	ppm	ASTM D5185m 0	<b>0</b>	2	4
Zinc	ppm	ASTM D5185m 0	<b>3</b>	2	15
Sulfur	ppm	ASTM D5185m 23500	<b>22543</b>	19405	20570

## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >25	<b>1</b>	<1	<1
Sodium	ppm	ASTM D5185m	<b>13</b>	8	9
Potassium	ppm	ASTM D5185m >20	<b>0</b>	1	<1
Water	%	ASTM D6304 >0.05	<b>0.017</b>	0.013	0.015
ppm Water	ppm	ASTM D6304 >500	<b>174</b>	134.4	153.2






## FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		<b>11302</b>	5416	9710
Particles >6µm	ASTM D7647	>1300	<b>▲ 3382</b>	902	▲ 2393
Particles >14µm	ASTM D7647	>80	<b>▲ 213</b>	61	▲ 174
Particles >21µm	ASTM D7647	>20	<b>▲ 50</b>	17	▲ 41
Particles >38µm	ASTM D7647	>4	<b>2</b>	1	▲ 4
Particles >71µm	ASTM D7647	>3	<b>0</b>	0	0
Oil Cleanliness	ISO 4406 (c)	>--/17/13	<b>▲ 21/19/15</b>	20/17/13	▲ 20/18/15

## FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045 1.0	<b>0.39</b>	0.33	0.37

# OIL ANALYSIS REPORT




PARAMETER	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	VLITE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 45	45.3	46.4	46.5

**SAMPLE IMAGES**

method	limit/base	current	history1	history2
Color				
Bottom				



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : KCPA013921 **Received** : 21 Mar 2024  
**Lab Number** : 06125694 **Tested** : 22 Mar 2024  
**Unique Number** : 10939845 **Diagnosed** : 25 Mar 2024 - Don Baldrige  
**Test Package** : IND 2 ( Additional Tests: KF, PritCount )

**FINE LINE GRAPHICS INC**  
 8229 MELROSE DR  
 LENEXA, KS  
 US 66214  
 Contact: M. DECKER  
 mdecker@flgcorp.com  
 T:  
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)