KAESER COMPRESSORS
Built for a lifetime.

OIL ANALYSIS REPORT

Sample Rating Trend



WATER

Machine Id
KAESER 3462043 (S/N 1053)
Component
Compressor
Fluid
KAESER SIGMA (OEM) S-460 (--- LTR)

DIAGNOSIS

Recommendation

The filter change at the time of sampling has been noted. We were unable to perform a particle count due to a high concentration of particles present in this sample. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition.

Wear

All component wear rates are normal.

Contamination

Appearance is hazy. There is a moderate amount of visible silt present in the sample. There is a light concentration of water present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number		Client Info		**KCPA013268**	KCP48006D	KCP52665
Sample Date		Client Info		**04 Mar 2024**	07 Aug 2023	06 Dec 2022
Machine Age	hrs	Client Info		**3683**	3260	3042
Oil Age	hrs	Client Info		**423**	399	181
Oil Changed		Client Info		**Not Changd**	Changed	Not Changd
Sample Status				**ABNORMAL**	NORMAL	NORMAL

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	**0**	0	0
Chromium	ppm	ASTM D5185m	>10	**0**	0	0
Nickel	ppm	ASTM D5185m	>3	**0**	0	0
Titanium	ppm	ASTM D5185m	>3	**0**	0	0
Silver	ppm	ASTM D5185m	>2	**0**	0	0
Aluminum	ppm	ASTM D5185m	>10	**0**	1	<1
Lead	ppm	ASTM D5185m	>10	**0**	0	0
Copper	ppm	ASTM D5185m	>50	**0**	<1	<1
Tin	ppm	ASTM D5185m	>10	**0**	0	0
Vanadium	ppm	ASTM D5185m		**0**	<1	0
Cadmium	ppm	ASTM D5185m		**0**	0	0

ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		**0**	0	0
Barium	ppm	ASTM D5185m	90	**28**	0	11
Molybdenum	ppm	ASTM D5185m		**0**	0	0
Manganese	ppm	ASTM D5185m		**<1**	0	0
Magnesium	ppm	ASTM D5185m	90	**20**	60	66
Calcium	ppm	ASTM D5185m	2	**0**	0	<1
Phosphorus	ppm	ASTM D5185m		**0**	0	26
Zinc	ppm	ASTM D5185m		**0**	0	9
Sulfur	ppm	ASTM D5185m		**21217**	22678	21462

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	**0**	<1	2
Sodium	ppm	ASTM D5185m		**3**	16	17
Potassium	ppm	ASTM D5185m	>20	**0**	2	1
Water	%	ASTM D6304	>0.05	▲ **0.130**	0.023	0.030
ppm Water	ppm	ASTM D6304	>500	▲ **1300**	238.3	309.5

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		**---**	1733	2722
Particles >6µm		ASTM D7647	>1300	**---**	380	551
Particles >14µm		ASTM D7647	>80	**---**	19	37
Particles >21µm		ASTM D7647	>20	**---**	4	16
Particles >38µm		ASTM D7647	>4	**---**	0	7
Particles >71µm		ASTM D7647	>3	**---**	0	3
Oil Cleanliness		ISO 4406 (c)	>--/17/13	**---**	18/16/11	19/16/12

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	**0.23**	0.30	0.36

KAESER COMPRESSORS
Built for a lifetime.

OIL ANALYSIS REPORT







VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	**NONE**	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	**NONE**	NONE	NONE
Precipitate	scalar	*Visual	NONE	**NONE**	NONE	NONE
Silt	scalar	*Visual	NONE	▲ **MODER**	NONE	NONE
Debris	scalar	*Visual	NONE	**NONE**	NONE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	**NONE**	NONE	NONE
Appearance	scalar	*Visual	NORML	● **HAZY**	NORML	NORML
Odor	scalar	*Visual	NORML	**NORML**	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	**0.2%**	NEG	NEG
Free Water	scalar	*Visual		**NEG**	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	**43.5**	43.6	43.7

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color					
Bottom					

GRAPHS









Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KCPA013268
Lab Number : 06125708
Unique Number : 10939859
Test Package : IND 2 (Additional Tests: KF, PrtCount)

Received : 21 Mar 2024
Tested : 26 Mar 2024
Diagnosed : 26 Mar 2024 - Jonathan Hester

To discuss this sample report, contact Customer Service at 1-800-237-1369.
** - Denotes test methods that are outside of the ISO 17025 scope of accreditation.*
Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

LOCKHEED MARTIN
6801 ROSELL ST
FORT BENNING, GA
US 31905
Contact: FRANK SOLARES
frank.solares@onevaliant.com
T:
F: