


OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id 7174177 (S/N 1265)

Component

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		May2020	Nov2020 May2021	Dec2021 Aug2022 Sep2023	Mar2024	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA015375	KC126177	KC98290
Sample Date		Client Info		12 Mar 2024	11 Sep 2023	03 Aug 2022
Machine Age	hrs	Client Info		30276	25968	16598
Oil Age	hrs	Client Info		7684	0	3000
Oil Changed		Client Info		Changed	N/A	Changed
Sample Status				NORMAL	NORMAL	NORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	<1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	<1	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	0	3	<1
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	1	5	5
Tin	ppm	ASTM D5185m	>10	0	<1	0
Antimony	ppm	ASTM D5185m				
Vanadium	ppm	ASTM D5185m		0	<1	0
Cadmium	ppm	ASTM D5185m		0	<1	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	14	2	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	<1	0
Magnesium	ppm	ASTM D5185m	90	59	50	25
Calcium	ppm	ASTM D5185m	2	<1	1	0
Phosphorus	ppm	ASTM D5185m		0	3	4
Zinc	ppm	ASTM D5185m		0	0	<1
Sulfur	ppm	ASTM D5185m		20797	19055	17993
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	<1	<1
Sodium	ppm	ASTM D5185m		10	11	9
Potassium	ppm	ASTM D5185m	>20	0	3	1
Water	%	ASTM D6304	>0.05	0.012	0.020	0.025
ppm Water	ppm	ASTM D6304	>500	128	203.0	259.0
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		2786	1077	2042
Particles >6µm		ASTM D7647	>1300	983	324	869
Particles >14μm		ASTM D7647	>80	52	29	8
Particles >21µm		ASTM D7647	>20	12	8	2
Particles >38μm		ASTM D7647	>4	0	2	0
Particles >71μm		ASTM D7647	>3	0	1	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	19/17/13	17/16/12	18/17/10
FLUID DEGRADA	TION	method	limit/base	current	history1	history2

0.31

0.26



OIL ANALYSIS REPORT



Test Package: IND 2 (Additional Tests: KF, PrtCount)

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Certificate L2367

T: F:

Contact: LAWRENCE

lawrence@nckc.com