


PROBLEM SUMMARY



Area
ACS-46-5 [417434]
 Machine Id
ATLAS COPCO AII357389 - JOHNSON AND JOHNSON
 Component
Compressor





Sample Rating Trend



WATER



COMPONENT CONDITION SUMMARY



RECOMMENDATION

We advise that you follow the water drain-off procedure for this component. We recommend an early resample to monitor this condition.

PROBLEMATIC TEST RESULTS

Sample Status				SEVERE	NORMAL	NORMAL
Water	%	ASTM D6304	>0.1	▲ 13.6	---	---
ppm Water	ppm	ASTM D6304	>1000	▲ 136000	---	---
Silt	scalar	*Visual	NONE	▲ HEAVY	NONE	NONE
Debris	scalar	*Visual	NONE	▲ MODER	VLITE	NONE
Emulsified Water	scalar	*Visual	>0.1	▲ 0.2%	NEG	NEG

Customer Id: UCAIRCAR
 Sample No.: UCH06125743
 Lab Number: 06125743
 Test Package: IND 2



To manage this report scan the QR code

To discuss the diagnosis or test data:
 Jonathan Hester +1 919-379-4092 x4092
jhester@wearcheckusa.com

To change component or sample information:
 Customer Service +1 1-800-237-1369
customerservice@wearcheck.com

RECOMMENDED ACTIONS

Action	Status	Date	Done By	Description
Water Drain-off	---	---	?	We advise that you follow the water drain-off procedure for this component.
Resample	---	---	?	We recommend an early resample to monitor this condition.

HISTORICAL DIAGNOSIS

20 Apr 2022 Diag: Doug Bogart

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

[view report](#)



31 Jan 2022 Diag: Angela Borella

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

[view report](#)



12 Oct 2021 Diag: Angela Borella

NORMAL



Resample at the next service interval to monitor. All component wear rates are normal. There is no indication of any contamination in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

[view report](#)




OIL ANALYSIS REPORT



Area
ACS-46-5 [417434]
 Machine Id
ATLAS COPCO AII357389 - JOHNSON AND JOHNSON
 Component
Compressor

Sample Rating Trend



WATER



DIAGNOSIS

▲ Recommendation

We advise that you follow the water drain-off procedure for this component. We recommend an early resample to monitor this condition.

● Wear

An increase in the iron level is noted.

▲ Contamination

Appearance is milky. There is a high concentration of water present in the oil. Moderate concentration of visible dirt/debris present in the oil. There is a high amount of visible silt present in the sample.

● Fluid Condition

The oil viscosity is higher than normal. Additive levels indicate the addition of a different brand, or type of oil. The AN level is acceptable for this fluid.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		UCH06125743	UCH05534127	UCH05468900
Sample Date	Client Info		11 Mar 2024	20 Apr 2022	31 Jan 2022
Machine Age	hrs	Client Info	167450	150910	149022
Oil Age	hrs	Client Info	2967	8473	6585
Oil Changed	Client Info		Not Chngd	Changed	Not Chngd
Sample Status			SEVERE	NORMAL	NORMAL

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >50	● 31	0	0
Chromium	ppm	ASTM D5185m >10	0	0	0
Nickel	ppm	ASTM D5185m	<1	0	0
Titanium	ppm	ASTM D5185m	0	0	0
Silver	ppm	ASTM D5185m	0	0	0
Aluminum	ppm	ASTM D5185m >25	<1	<1	<1
Lead	ppm	ASTM D5185m >25	0	<1	0
Copper	ppm	ASTM D5185m >50	0	<1	<1
Tin	ppm	ASTM D5185m >15	2	0	0
Antimony	ppm	ASTM D5185m	---	---	0
Vanadium	ppm	ASTM D5185m	0	0	0
Cadmium	ppm	ASTM D5185m	<1	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m 1.5	5	0	0
Barium	ppm	ASTM D5185m 0	● 117	0	0
Molybdenum	ppm	ASTM D5185m 0	0	0	0
Manganese	ppm	ASTM D5185m 0.3	<1	0	0
Magnesium	ppm	ASTM D5185m 0	2	0	0
Calcium	ppm	ASTM D5185m 0	<1	0	0
Phosphorus	ppm	ASTM D5185m 406	● 6	328	360
Zinc	ppm	ASTM D5185m 0	0	0	0
Sulfur	ppm	ASTM D5185m 1283	● 590	717	611






CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >25	<1	4	4
Sodium	ppm	ASTM D5185m	77	0	0
Potassium	ppm	ASTM D5185m >20	6	<1	0
Water	%	ASTM D6304 >0.1	▲ 13.6	---	---
ppm Water	ppm	ASTM D6304 >1000	▲ 136000	---	---

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045 0.463	0.27	0.44	0.30


OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2	
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	▲ HEAVY	NONE	NONE
Debris	scalar	*Visual	NONE	▲ MODER	VLITE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	● MILKY	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	▲ 0.2%	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 40°C	cSt	ASTM D445	47.9	● 72.4	41.5	41.4

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : UCH06125743 **Received** : 21 Mar 2024
Lab Number : 06125743 **Tested** : 26 Mar 2024
Unique Number : 10939894 **Diagnosed** : 26 Mar 2024 - Jonathan Hester
Test Package : IND 2 (Additional Tests: KF)

AIRMATIC COMPRESSOR SYSTEMS
 700 WASHINGTON AVE
 CARLSTADT, NJ
 US 07072
 Contact: ELVIN DIAZ
 ediaz@airmaticcompressor.com;canastasio@wearcheckusa.com
 T: (800)864-7621
 F: (201)342-6241

Certificate L2367
 To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)