


OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id KAESER ASD 30T 4083211 (S/N 1214)

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Oct2016 Nov2	017 Apr2018 Dec2018 Jun2	019 Dec2019 Jun2020 Nov2020 Jun20	023 Mar2024	
SAMPLE INFOR	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA013018	KCPA002228	KCP31231
Sample Date		Client Info		08 Mar 2024	12 Jun 2023	05 Nov 2020
Machine Age	hrs	Client Info		55935	51748	46531
Oil Age	hrs	Client Info		1187	0	3330
Oil Changed		Client Info		Changed	N/A	Not Changd
Sample Status				NORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	0
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	0	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	0	0	0
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	11	18	14
Tin	ppm	ASTM D5185m	>10	0	0	0
Antimony	ppm	ASTM D5185m				0
Vanadium	ppm	ASTM D5185m		0	<1	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	7
Barium	ppm	ASTM D5185m	90	0	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0	0
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m	100	0	2	3
Calcium	ppm	ASTM D5185m	0	0	0	0
Phosphorus	ppm	ASTM D5185m	0	0	1	0
Zinc	ppm	ASTM D5185m	0	56	17	12
Sulfur	ppm	ASTM D5185m	23500	19603	19975	14233
CONTAMINANTS	6	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	<1	0
Sodium	ppm	ASTM D5185m		<1	2	2
Potassium	ppm	ASTM D5185m	>20	0	0	0
Water	%	ASTM D6304	>0.05	0.007	0.008	0.006
ppm Water	ppm	ASTM D6304	>500	75	86.5	65.8
FLUID CLEANLIN	NESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		3349		4467
Particles >6µm		ASTM D7647	>1300	870		1519
Particles >14µm		ASTM D7647	>80	51		<u> </u>
Particles >21μm		ASTM D7647	>20	13		△ 61
Particles >38µm		ASTM D7647	>4	0		4
Particles >71µm		ASTM D7647	>3	0		2
Oil Cleanliness		ISO 4406 (c)	>/17/13	19/17/13		△ 18/15
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
A	1/011/	40TM D00 :=		0.44	0.40	0.000



OIL ANALYSIS REPORT







Sample No. Lab Number

: KCPA013018 : 06130619

Received **Tested** Unique Number: 10950084 Diagnosed

: 28 Mar 2024

: 30 Mar 2024 - Don Baldridge

Test Package: IND 2 (Additional Tests: KF, PrtCount)

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

1223 CROWLEY DR

CARROLLTON, TX US 75006

Contact: SERVICE MANAGER

Contact/Location: SERVICE MANAGER ? - EXACAR

T: F: