

## **OIL ANALYSIS REPORT**

### ULTRA FG INGERSOLL RAND Gilster Mary Lee - Shredded (S/N F5121U92) Component

Air Compressor

#### Recommendation

Resample at the next service interval to monitor.

#### Wear


All component wear rates are normal.

#### Contamination

There is no indication of any contamination in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.






SAMPLE INFORM	NATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UCH0000451		
Sample Date		Client Info		18 Mar 2024		
Machine Age	hrs	Client Info		19656		
Oil Age	hrs	Client Info		2765		
Oil Changed		Client Info		Oil Added		
Sample Status				NORMAL		
CONTAMINATION	N	method	limit/base	current	history1	history2
Water		WC Method	>0.6	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	1		
Chromium	ppm	ASTM D5185m	>4	0		
Nickel	ppm	ASTM D5185m	>4	0		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>10	0		
Lead	ppm	ASTM D5185m	>20	0		
Copper	ppm	ASTM D5185m	>40	2		
Tin	ppm	ASTM D5185m	>5	0		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		<1		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m		0		
Calcium	ppm	ASTM D5185m		42		
Phosphorus	ppm	ASTM D5185m		317		
Zinc	ppm	ASTM D5185m		0		
Sulfur	ppm	ASTM D5185m		752		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0		
Sodium	ppm	ASTM D5185m		18		
Potassium	ppm	ASTM D5185m	>20	0		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.20		



Mar18/24

# **OIL ANALYSIS REPORT**

VISUAL



	VISUAL		method	limit/base	current	history1	history2
	White Metal	scalar	*Visual	NONE	NONE		
	Yellow Metal	scalar	*Visual	NONE	NONE		
	Precipitate	scalar	*Visual	NONE	NONE		
	Silt	scalar	*Visual	NONE	NONE		
	Debris	scalar	*Visual	NONE	NONE		
	Sand/Dirt	scalar	*Visual	NONE	NONE		
Mar18,24	Appearance	scalar	*Visual	NORML	NORML		
Marl	Odor	scalar	*Visual	NORML	NORML		
	Emulsified Water	scalar	*Visual	>0.6	NEG		
	Free Water	scalar	*Visual		NEG		
	FLUID PROPERT		method	limit/base	current	history1	history2
	Visc @ 40°C	cSt	ASTM D445	46.0	53.2		
	SAMPLE IMAGES	5	method	limit/base	current	history1	history2
Mar18/24 +	Color					no image	no image
	Bottom					no image	no image
	B B B B B B B B B B B B B B B B B B B	s		Mar18/24			
	udd 4 4 4 4 4 4 4 4 4 4 4 4 4			Mar18/24			
	Viscosity @ 40°C			_	Acid Number		
	60 55 (2,0)b) 50 45 45 45 45 45 45 45 45 45 45 45 45 45			0.2 0.1 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0	5		
Laboratory Sample No. Lab Number Unique Number Test Package discuss this sample report,	: 10951581 : IND 2	Recei Teste Diagr	ived : 28 id : 29 nosed : 02 800-237-1369	8 Mar 2024 9 Mar 2024 Apr 2024 - Ang 9.	ela Borella	ntact: RACHEL	RGET STREE NT LOUIS, MO US 6313

Submitted By: RACHEL VON HATTEN