


OIL ANALYSIS REPORT

ULTRA COOLANT 46 Machine Id PG3113U06355 - P&R MFG

Component

Compressor



DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

14/- ---

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UCH06132175		
Sample Date		Client Info		08 Mar 2024		
Machine Age	hrs	Client Info		78996		
Oil Age	hrs	Client Info		2000		
Oil Changed		Client Info		Not Changd		
Sample Status				NORMAL		
CONTAMINATIO	N	method	limit/base	current	history1	history2
Water		WC Method	>0.8	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m		0		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>25	0		
Lead	ppm	ASTM D5185m	>25	0		
Copper	ppm	ASTM D5185m	>50	<1		
Tin	ppm	ASTM D5185m	>15	0		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	2	<1		
Barium	ppm	ASTM D5185m	525	480		
Molybdenum	ppm	ASTM D5185m	10	0		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m	5	0		
Calcium	ppm	ASTM D5185m	10	1		
Phosphorus	ppm	ASTM D5185m	250	9		
Zinc	ppm	ASTM D5185m	100	7		
Sulfur	ppm	ASTM D5185m	400	345		
CONTAMINANTS	3	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1		
Sodium	ppm	ASTM D5185m		30		
Potassium	ppm	ASTM D5185m	>20	<1		
FLUID DEGRADA	ATION _	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.25		




OIL ANALYSIS REPORT





VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE		
Yellow Metal	scalar	*Visual	NONE	NONE		
Precipitate	scalar	*Visual	NONE	NONE		
Silt	scalar	*Visual	NONE	NONE		
Debris	scalar	*Visual	NONE	NONE		
Sand/Dirt	scalar	*Visual	NONE	NONE		
Appearance	scalar	*Visual	NORML	NORML		
Odor	scalar	*Visual	NORML	NORML		
Emulsified Water	scalar	*Visual	>0.8	NEG		
Free Water	scalar	*Visual		NEG		
FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	51.7		
SAMPLE IMAGES		method	limit/base	current	history1	history2

Color no image no image **Bottom** no image no image **GRAPHS**













Certificate L2367

Laboratory Sample No.

Lab Number : 06132175

Test Package : IND 2

: UCH06132175 Unique Number : 10951640

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received

: 28 Mar 2024 **Tested** : 29 Mar 2024 Diagnosed

: 02 Apr 2024 - Angela Borella

A-L-L EQUIPMENT INC 204 38TH ST MOLINE, IL

US 61265 Contact: KEVIN DESPOT kevind@a-l-lequipment.com

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: (309)762-9950

Contact/Location: KEVIN DESPOT - UCALLMOL

T: (815)877-7000