




OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id
MTNM01BE
Component
Biogas Engine
Fluid
SHELL MYSELLA S5 N 40 (160 GAL)

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0775214	WC0775223	WC0775260
Sample Date	Client Info		26 Mar 2024	19 Mar 2024	11 Mar 2024
Machine Age	hrs	Client Info	41861	41782	41696
Oil Age	hrs	Client Info	14	435	349
Oil Changed	Client Info		N/A	N/A	N/A
Sample Status			NORMAL	SEVERE	NORMAL

CONTAMINATION

	method	limit/base	current	history1	history2
Fuel	WC Method	>4.0	<1.0	<1.0	<1.0
Water	WC Method	>0.11	NEG	NEG	NEG
Glycol	WC Method		NEG	NEG	NEG

WEAR METALS

	method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m	>15	3	6	5
Chromium	ppm	ASTM D5185m	>4	0	<1	<1
Nickel	ppm	ASTM D5185m		<1	<1	<1
Titanium	ppm	ASTM D5185m		0	<1	<1
Silver	ppm	ASTM D5185m		0	<1	0
Aluminum	ppm	ASTM D5185m	>6	3	4	3
Lead	ppm	ASTM D5185m	>9	0	<1	0
Copper	ppm	ASTM D5185m	>6	<1	2	1
Tin	ppm	ASTM D5185m	>4	1	5	3
Vanadium	ppm	ASTM D5185m		0	<1	0
Cadmium	ppm	ASTM D5185m		0	0	0

ADDITIVES

	method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m		4	5	5
Barium	ppm	ASTM D5185m		0	2	0
Molybdenum	ppm	ASTM D5185m		4	6	6
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m		25	29	28
Calcium	ppm	ASTM D5185m		1488	1819	1586
Phosphorus	ppm	ASTM D5185m	300	301	367	355
Zinc	ppm	ASTM D5185m		390	484	441
Sulfur	ppm	ASTM D5185m		3399	3962	3518

CONTAMINANTS

	method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m	>181	99	▲ 221	177
Sodium	ppm	ASTM D5185m	>21	1	0	0
Potassium	ppm	ASTM D5185m	>20	0	2	1

INFRA-RED




	method	limit/base	current	history1	history2	
Soot %	%	*ASTM D7844		0.1	0.1	0.1
Nitration	Abs/cm	*ASTM D7624	>16	4.2	5.2	5.0
Sulfation	Abs/.1mm	*ASTM D7415		19.4	23.4	22.5

FLUID DEGRADATION

	method	limit/base	current	history1	history2	
Oxidation	Abs/.1mm	*ASTM D7414		12.8	16.4	15.4
Acid Number (AN)	mg KOH/g	ASTM D8045		0.67	1.74	1.43
Base Number (BN)	mg KOH/g	ASTM D2896	4.5	4.17	3.15	3.37











OIL ANALYSIS REPORT



VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.11	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2	
Visc @ 100°C	cSt	ASTM D445	13.5	13.4	13.7	13.5

GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0775214
Lab Number : **06132225**
Unique Number : 10951690
Test Package : MOB 2

Received : 28 Mar 2024
Tested : 29 Mar 2024
Diagnosed : 02 Apr 2024 - Sean Felton

EDL NA Recips-Morgantown
Morgantown Powerstation, 950 Shiloh
Morgantown, PA
US 19543
Contact: ARON GUNN
aron.gunn@edlenergy.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: