

OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL



Grand Blanc CAT 4 GBLM04BE

Biogas Engine

CHEVRON HDAX 9500 GAS ENGINE OIL 40 (--- GAL)

ENGINE OIL 40 (·	GAL)	w2023 Apr20	23 May2023 Jul2023	Sep2023 Oct2023 Dec2023	Feb2024	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0905743	WC0905733	WC0905735
Sample Date		Client Info		25 Mar 2024	12 Mar 2024	07 Mar 2024
Machine Age	hrs	Client Info		68503	68245	68102
Oil Age	hrs	Client Info		200	950	807
Oil Changed		Client Info		Changed	Not Changd	Not Changd
Sample Status				NORMAL	SEVERE	ABNORMAL
CONTAMINATIO	N	method	limit/base	current	history1	history2
Fuel		WC Method	>4.0	<1.0	<1.0	<1.0
Water		WC Method	>.11	NEG	NEG	NEG
Glycol		WC Method		NEG	NEG	NEG
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>15	2	8	7
Chromium	ppm	ASTM D5185m	>4	0	<1	0
Nickel	ppm	ASTM D5185m		0	0	0
Titanium	ppm	ASTM D5185m		0	0	0
Silver	ppm	ASTM D5185m		0	0	0
Aluminum	ppm	ASTM D5185m	>6	1	2	2
Lead	ppm	ASTM D5185m	>9	<1	4	4
Copper	ppm	ASTM D5185m		<1	2	<1
Tin	ppm	ASTM D5185m	>4	0	3	2
Vanadium	ppm	ASTM D5185m		0	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		4	3	2
Barium	ppm	ASTM D5185m		0	0	0
Molybdenum	ppm	ASTM D5185m		<1	2	2
Manganese	ppm	ASTM D5185m		0	0	0
Magnesium	ppm	ASTM D5185m		7	14	12
Calcium	ppm	ASTM D5185m		1591	1907	1998
Phosphorus	ppm	ASTM D5185m		232	282	281
Zinc	ppm	ASTM D5185m		278	365	350
Sulfur	ppm	ASTM D5185m		2677	3397	3173
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>181	75	▲ 204	179
Sodium	ppm	ASTM D5185m	>21	2	0	1
Potassium	ppm	ASTM D5185m	>20	0	2	0
INFRA-RED		method	limit/base	current	history1	history2
Soot %	%	*ASTM D7844		0	0.1	0
Nitration	Abs/cm	*ASTM D7624		5.4	6.0	5.8
Sulfation	Abs/.1mm	*ASTM D7415		19.0	26.3	25.3
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Oxidation	Abs/.1mm	*ASTM D7414		10.8	16.8	15.9
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	1.18	▲ 2.56	▲ 2.46
Base Number (BN)	mg KOH/g	ASTM D2896	5.4	3.69	2.01	2.49
		. 10 1 11 02000	5.1	0.00		2.10

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor. (Customer Sample Comment: 200 hour oil sample after fluid and filter change.)

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition


The BN result indicates that there is suitable alkalinity remaining in the oil. The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


Submitted By: Tony Saint Marie

Page 1 of 2



OIL ANALYSIS REPORT





VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal sca		*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>.11	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 100°C	cSt	ASTM D445	13.4	13.3	13.9	13.9
GRAPHS						
Iron (ppm)			1	Lead (ppm)		
25 20 Severe			19	Severe		
Abaamal			10	Abnormal	uluuluul	
E 15 - 6			Mdd	$\int \int $		
5 00000	N	N-A	1		MAN	AMA
		VVV		Ind.		VVI
Mar13/23 Apr26/23 May26/23 Jul19/23	Sep6/23	0ct26/23 Dec18/23	-7/610	Mar13/23 Apr26/23 May26/23	Jul19/23 Sep6/23 Oct26/23	Dec18/23 Feb15/24
2770 (P40) (P40) (P40)	So and a second s	Dec Cab	5	C1224		Der Feb
Aluminum (ppm)				Chromium (p	pm)	
12 10				Severe		
8-				Abnormal		·····
E 6- Abnormal			udd			
2 200	Λ.	-00		1		
	Y V	\sim \sim				
Mar13/23 Apr26/23 May26/23 Jul19/23	Sep6/23	Oct26/23 Dec18/23	17/C1	Mar13/23 Apr26/23 May26/23	Jul19/23 Sep6/23 Oct26/23	Dec18/23 Feb15/24
	So and a second s	Dec Cab	5	20001	Ju Se Oct	Der Feb
Copper (ppm)			250	Silicon (ppm)		
Severe			200	Severe		
15-					1.11	AAA
E 10 - Abnormal			E 150	VV	VVVI	/ V V / I
5- Abnormal	~		50			V 1
		h				
Mar13/23 Apr26/23 May26/23 Jul19/23	Sep6/23	0ct26/23 Dec18/23	7/010	Mar13/23 Apr26/23 May26/23	Jul19/23 Sep6/23 Oct26/23	Dec18/23 Feb15/24
2750 (PAN) (PAN)	So and a second s	Det Det	5			Fet.
Viscosity @ 100°C				Base Number		
18 Severe			(B/H0			
			.6.10 Base Number (mg KOH/g) 2.1	Base	~ ^	
01) 3 14- Base			Ja 4.0	Severe	Vyy	MAN /
Abnormal			N 2.0		10	24
10		m m =	0.0) • • • • • • • • • • • • • • • • • • •		+ 3
5 5 5	Sep6/23	Oct26/23 Dec18/23 Eah15/24	7/010	Mar13/23 Apr26/23 May26/23	Jul19/23 Sep6/23 Oct26/23	Dec18/23 Feb15/24
Mar13/23 Apr26/23 May26/23 Jul19/23	43					



Test Package : MOB 2 Certificate L2367 To discuss this sample report, contact Customer Service at 1-800-237-1369. tony.saintmarie@edlenergy.com * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact: Tony Saint Marie

T:

F: