


FUEL REPORT

VA Ann Arbor Healthcare System [8008] [VA Ann Arbor Healthcare System] TANK 900 KW BLDG 15 UST

Diesel Fuel

No.2 DIESEL FUEL (ULTRALOW SULPHUR





DIAGNOSIS

Recommendation

All laboratory tests indicate that this sample meets specifications for No.2 diesel fuel.

Corrosion

All metal levels are normal indicating no corrosion in the system.

Contaminants

There is no bacteria or fungus (yeast and/or mold) indicated in the sample. The water content is negligible. There is no indication of any contamination in the fuel. The amount and size of particulates present in the system are acceptable.


Fuel Condition

Sulfur value derived by ASTM D5453 method for ULSD validation.

R) (4000 GAL)			1	Mar2024		
SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC06132845		
Sample Date		Client Info		14 Mar 2024		
Machine Age	hrs	Client Info		0		
Sample Status	1113	Ollotte Itilio		NORMAL		
	EDTIEC	us atland	li		hinto4	history.O
PHYSICAL PROP	ERITES		limit/base	current	history1	history2
Specific Gravity	1 1	*ASTM D1298	0.839	0.853		
Fuel Color	text	*Visual Screen	Yllow	Red		
ASTM Color	scalar	*ASTM D1500	0.0	L4.5		
Visc @ 40°C	cSt	ASTM D445	3.0	2.59		
Pensky-Martens Flash Point	°C	*PMCC Calculated	52	66.4		
SULFUR CONTE	٧T	method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m	10	1584		
Sulfur (UVF)	ppm	ASTM D5453		1377		
DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D86	165	173		
5% Distillation Point	°C	ASTM D86		202		
10% Distill Point	°C	ASTM D86	201	213		
15% Distillation Point	°C	ASTM D86		222		
20% Distill Point	°C	ASTM D86	216	229		
30% Distill Point	°C	ASTM D86	230	241		
40% Distill Point	°C	ASTM D86	243	252		
50% Distill Point	°C	ASTM D86	255	263		
60% Distill Point	°C	ASTM D86	267	273		
70% Distill Point	°C	ASTM D86	280	284		
80% Distill Point	°C	ASTM D86	295	296		
85% Distillation Point	°C	ASTM D86		304		
90% Distill Point	°C	ASTM D86	310	313		
95% Distillation Point	°C	ASTM D86		327		
Final Boiling Point	°C	ASTM D86	341	338		
Distillation Residue	%	ASTM D86	3.0	1.4		
Distillation Loss	%	ASTM D86	3.0	0.3		
IGNITION QUALIT	Υ	method	limit/base	current	history1	history2
API Gravity		ASTM D7777	37.7	34.4		
Cetane Index		ASTM D4737	<40.0	42.6		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	0		
Sodium	ppm	ASTM D5185m	< 0.1	<1		
Potassium	ppm	ASTM D5185m	<0.1	0		
Water	%	ASTM D6304	< 0.05	0.004		
ppm Water	ppm	ASTM D6304	<500	43		
% Gasoline	%	*In-House	< 0.50	0.0		
% Biodiesel	%	*In-House	<20.0	0.0		



FUEL REPORT







Sample No.

: WC06132845 Lab Number : 06132845

Unique Number : 10952310

Tested Diagnosed Test Package : DF-2 (Additional Tests: Fuel, Screen)

Certificate 12367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

210 POWELL DR SUMMERVILLE, SC US 29483

Contact: AJAY EL Ajay@prsfuel.com T: (843)225-1777

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

: 10 Apr 2024

: 10 Apr 2024 - Doug Bogart