




OIL ANALYSIS REPORT

Sample Rating Trend



WATER



Machine Id

MACHINE 3 PUMP 1

Component

Hydraulic System

Fluid

AW HYDRAULIC OIL ISO 46 (--- GAL)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

Wear

The iron level is abnormal. The copper level is abnormal.

Contamination

There is a moderate amount of visible silt present in the sample. There is a light concentration of water present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	WC0908008	WC0850241	---
Sample Date	Client Info	28 Mar 2024	13 Dec 2023	---
Machine Age	hrs	Client Info	0	---
Oil Age	hrs	Client Info	0	---
Oil Changed	Client Info	N/A	N/A	---
Sample Status		ABNORMAL	SEVERE	---

WEAR METALS

method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m >20	▲ 25	▲ 29	---
Chromium	ppm	ASTM D5185m >20	1	<1	---
Nickel	ppm	ASTM D5185m >20	<1	<1	---
Titanium	ppm	ASTM D5185m	<1	0	---
Silver	ppm	ASTM D5185m	0	<1	---
Aluminum	ppm	ASTM D5185m >20	3	1	---
Lead	ppm	ASTM D5185m >20	<1	<1	---
Copper	ppm	ASTM D5185m >20	▲ 45	▲ 35	---
Tin	ppm	ASTM D5185m >20	1	<1	---
Vanadium	ppm	ASTM D5185m	<1	0	---
Cadmium	ppm	ASTM D5185m	<1	<1	---

ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m 5	0	0	---
Barium	ppm	ASTM D5185m 5	<1	0	---
Molybdenum	ppm	ASTM D5185m 5	0	0	---
Manganese	ppm	ASTM D5185m	0	<1	---
Magnesium	ppm	ASTM D5185m 25	<1	1	---
Calcium	ppm	ASTM D5185m 200	6	2	---
Phosphorus	ppm	ASTM D5185m 300	480	459	---
Zinc	ppm	ASTM D5185m 370	15	22	---
Sulfur	ppm	ASTM D5185m 2500	541	561	---

CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m >15	4	4	---
Sodium	ppm	ASTM D5185m	0	<1	---
Potassium	ppm	ASTM D5185m >20	1	3	---
Water	%	ASTM D6304 >0.05	▲ 0.108	▲ 0.974	---
ppm Water	ppm	ASTM D6304 >500	▲ 1080	▲ 9740	---

FLUID CLEANLINESS






method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >5000	---	2514	---
Particles >6µm	ASTM D7647 >1300	---	● 1370	---
Particles >14µm	ASTM D7647 >160	---	● 233	---
Particles >21µm	ASTM D7647 >40	---	● 79	---
Particles >38µm	ASTM D7647 >10	---	12	---
Particles >71µm	ASTM D7647 >3	---	1	---
Oil Cleanliness	ISO 4406 (c) >19/17/14	---	● 19/18/15	---

FLUID DEGRADATION

method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045 0.57	0.17	0.19	---




OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	---
Silt	scalar	*Visual	NONE	▲ MODER	---
Debris	scalar	*Visual	NONE	NONE	---
Sand/Dirt	scalar	*Visual	NONE	NONE	---
Appearance	scalar	*Visual	NORML	NORML	---
Odor	scalar	*Visual	NORML	NORML	---
Emulsified Water	scalar	*Visual	>0.05	0.2%	▲ 0.2%
Free Water	scalar	*Visual		NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 46	44.8	42.6	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0908008 **Received** : 29 Mar 2024
Lab Number : 06133275 **Tested** : 03 Apr 2024
Unique Number : 10952740 **Diagnosed** : 03 Apr 2024 - Jonathan Hester
Test Package : IND 2 (Additional Tests: KF)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

UNIVERSAL PURE
 2301 CENTENNIAL DR
 ARLINGTON, TX
 US 76011
 Contact: NICO LEEJAY
 NLeejay@universalpure.com
 T: (469)441-3632
 F: