




OIL ANALYSIS REPORT

Sample Rating Trend



WATER



Machine Id

MACHINE 2 PUMP 1

Component

Hydraulic System

Fluid

AW HYDRAULIC OIL ISO 46 (--- GAL)

DIAGNOSIS

▲ Recommendation

We advise that you check for the source of water entry. We recommend you service the filters on this component. Resample at the next service interval to monitor. We were unable to perform a particle count due to a high concentration of particles present in this sample.

▲ Wear

The iron level is abnormal. The copper level is abnormal.

▲ Contamination

There is a light concentration of water present in the oil. There is a high amount of visible silt present in the sample.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		WC0908005	WC0850243	---
Sample Date	Client Info		28 Mar 2024	13 Dec 2023	---
Machine Age	hrs	Client Info	0	0	---
Oil Age	hrs	Client Info	0	0	---
Oil Changed	Client Info		N/A	N/A	---
Sample Status			ABNORMAL	ABNORMAL	---

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >20	▲ 21	15	---
Chromium	ppm	ASTM D5185m >20	<1	<1	---
Nickel	ppm	ASTM D5185m >20	0	<1	---
Titanium	ppm	ASTM D5185m	<1	0	---
Silver	ppm	ASTM D5185m	0	<1	---
Aluminum	ppm	ASTM D5185m >20	3	<1	---
Lead	ppm	ASTM D5185m >20	<1	<1	---
Copper	ppm	ASTM D5185m >20	▲ 20	14	---
Tin	ppm	ASTM D5185m >20	<1	<1	---
Vanadium	ppm	ASTM D5185m	<1	0	---
Cadmium	ppm	ASTM D5185m	<1	<1	---

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m 5	0	0	---
Barium	ppm	ASTM D5185m 5	<1	0	---
Molybdenum	ppm	ASTM D5185m 5	0	0	---
Manganese	ppm	ASTM D5185m	<1	<1	---
Magnesium	ppm	ASTM D5185m 25	<1	<1	---
Calcium	ppm	ASTM D5185m 200	4	0	---
Phosphorus	ppm	ASTM D5185m 300	456	453	---
Zinc	ppm	ASTM D5185m 370	12	1	---
Sulfur	ppm	ASTM D5185m 2500	500	535	---

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >15	3	3	---
Sodium	ppm	ASTM D5185m	0	1	---
Potassium	ppm	ASTM D5185m >20	1	2	---
Water	%	ASTM D6304 >0.05	▲ 0.168	▲ 0.277	---
ppm Water	ppm	ASTM D6304 >500	▲ 1680	▲ 2770	---

FLUID CLEANLINESS






	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>5000	---	▲ 102009	---
Particles >6µm	ASTM D7647	>1300	---	▲ 9797	---
Particles >14µm	ASTM D7647	>160	---	14	---
Particles >21µm	ASTM D7647	>40	---	4	---
Particles >38µm	ASTM D7647	>10	---	0	---
Particles >71µm	ASTM D7647	>3	---	0	---
Oil Cleanliness	ISO 4406 (c)	>19/17/14	---	▲ 24/20/11	---

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045 0.57	0.19	0.19	---




OIL ANALYSIS REPORT







PARAMETER	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	---
Silt	scalar	*Visual	NONE	▲ HEAVY	NONE
Debris	scalar	*Visual	NONE	NONE	---
Sand/Dirt	scalar	*Visual	NONE	NONE	---
Appearance	scalar	*Visual	NORML	NORML	---
Odor	scalar	*Visual	NORML	NORML	---
Emulsified Water	scalar	*Visual	>0.05	0.2%	---
Free Water	scalar	*Visual		NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	41.7	43.1

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
 Sample No. : WC0908005 Received : 29 Mar 2024
 Lab Number : 06133280 Tested : 03 Apr 2024
 Unique Number : 10952745 Diagnosed : 03 Apr 2024 - Jonathan Hester
 Test Package : IND 2 (Additional Tests: KF)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

UNIVERSAL PURE
 2301 CENTENNIAL DR
 ARLINGTON, TX
 US 76011
 Contact: NICO LEEJAY
 NLeejay@universalpure.com
 T: (469)441-3632
 F: