




OIL ANALYSIS REPORT

Sample Rating Trend



WATER



Area

RRJ

Machine Id

B-01-402 Biogas Blower Non-Drive End

Component

Non-Drive End Compressor

Fluid

GARDNER DENVER AEON PD (--- GAL)

DIAGNOSIS

Recommendation

We advise that you check for the source of water entry. We advise that you follow the water drain-off procedure for this component. Resample at the next service interval to monitor.

Wear

The iron level is abnormal. All other component wear rates are normal.

Contamination

There is a moderate concentration of water present in the oil. The amount and size of particulates present in the system are acceptable.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	WC0886374	WC0886377	WC0886388
Sample Date	Client Info	26 Mar 2024	27 Feb 2024	31 Jan 2024
Machine Age	hrs	Client Info	0	0
Oil Age	hrs	Client Info	0	0
Oil Changed	Client Info	N/A	N/A	N/A
Sample Status		ABNORMAL	ABNORMAL	SEVERE

WEAR METALS

method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m >50	▲ 51	▲ 59	▲ 87
Chromium	ppm	ASTM D5185m >10	4	2	4
Nickel	ppm	ASTM D5185m	<1	0	<1
Titanium	ppm	ASTM D5185m	<1	0	0
Silver	ppm	ASTM D5185m	0	0	0
Aluminum	ppm	ASTM D5185m >25	3	<1	2
Lead	ppm	ASTM D5185m >25	<1	0	<1
Copper	ppm	ASTM D5185m >50	1	0	<1
Tin	ppm	ASTM D5185m >15	1	1	2
Vanadium	ppm	ASTM D5185m	<1	0	0
Cadmium	ppm	ASTM D5185m	<1	0	0

ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m	<1	0	0
Barium	ppm	ASTM D5185m	0	0	0
Molybdenum	ppm	ASTM D5185m	0	0	0
Manganese	ppm	ASTM D5185m	<1	<1	<1
Magnesium	ppm	ASTM D5185m	<1	0	<1
Calcium	ppm	ASTM D5185m	5	<1	0
Phosphorus	ppm	ASTM D5185m	631	591	605
Zinc	ppm	ASTM D5185m	4	0	0
Sulfur	ppm	ASTM D5185m	662	811	718

CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m >25	4	4	5
Sodium	ppm	ASTM D5185m	0	0	0
Potassium	ppm	ASTM D5185m >20	<1	0	0
Water	%	ASTM D6304 >0.1	▲ 0.534	▲ 0.361	▲ 1.27
ppm Water	ppm	ASTM D6304 >1000	▲ 5340	▲ 3610	▲ 12700

FLUID CLEANLINESS






method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >10000	1740	---	9944
Particles >6µm	ASTM D7647 >2500	948	---	▲ 5417
Particles >14µm	ASTM D7647 >320	161	---	▲ 922
Particles >21µm	ASTM D7647 >80	54	---	▲ 311
Particles >38µm	ASTM D7647 >20	8	---	▲ 48
Particles >71µm	ASTM D7647 >4	1	---	▲ 5
Oil Cleanliness	ISO 4406 (c) >20/18/15	18/17/15	---	▲ 20/20/17

FLUID DEGRADATION

method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045	0.63	0.55	0.79




OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	▲ MODER	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	0.2%	▲ 0.2%
Free Water	scalar	*Visual	NEG	NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 214	212	209	209

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC0886374 **Received** : 29 Mar 2024
Lab Number : 06133285 **Tested** : 05 Apr 2024
Unique Number : 10952750 **Diagnosed** : 05 Apr 2024 - Jonathan Hester
Test Package : PLANT

GEVO Inc.
 2498 250th Street
 Doon, IA
 US 51235
 Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)