




OIL ANALYSIS REPORT

Sample Rating Trend



VISCOSITY



Machine Id
123
 Component
Hydraulic System
 Fluid
SHELL TELLUS 68 (42 GAL)

DIAGNOSIS

▲ Recommendation

We recommend you service the filters on this component if applicable. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

▲ Contamination

There is a high amount of silt (particulates < 14 microns in size) present in the oil.

● Fluid Condition

Viscosity of sample indicates oil is within ISO 46 range, advise investigate. Confirm oil type. The AN level is acceptable for this fluid.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			RP0042949	RP202491	---
Sample Date	Client Info			15 Mar 2024	20 Nov 2020	---
Machine Age	hrs	Client Info		3795	25000	---
Oil Age	hrs	Client Info		3795	25000	---
Oil Changed	Client Info			Not Chngd	Not Chngd	---
Sample Status				ABNORMAL	ATTENTION	---

WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>20	11	<1	---
Chromium	ppm	ASTM D5185m	>20	2	<1	---
Nickel	ppm	ASTM D5185m	>20	0	0	---
Titanium	ppm	ASTM D5185m		<1	0	---
Silver	ppm	ASTM D5185m		0	<1	---
Aluminum	ppm	ASTM D5185m	>20	3	0	---
Lead	ppm	ASTM D5185m	>20	<1	<1	---
Copper	ppm	ASTM D5185m	>20	2	2	---
Tin	ppm	ASTM D5185m	>20	<1	0	---
Antimony	ppm	ASTM D5185m		---	0	---
Vanadium	ppm	ASTM D5185m		<1	0	---
Cadmium	ppm	ASTM D5185m		<1	0	---






ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	---
Barium	ppm	ASTM D5185m		<1	0	---
Molybdenum	ppm	ASTM D5185m		<1	<1	---
Manganese	ppm	ASTM D5185m		<1	0	---
Magnesium	ppm	ASTM D5185m	11	4	<1	---
Calcium	ppm	ASTM D5185m	39	210	34	---
Phosphorus	ppm	ASTM D5185m	260	324	297	---
Zinc	ppm	ASTM D5185m	279	396	361	---

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	6	0	---
Sodium	ppm	ASTM D5185m		0	0	---
Potassium	ppm	ASTM D5185m	>20	2	<1	---
Water	%	ASTM D6304	>0.05	0.004	0.004	---
ppm Water	ppm	ASTM D6304	>500	49	47.5	---

FLUID CLEANLINESS		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>5000	▲ 71559	● 5347	---
Particles >6µm		ASTM D7647	>1300	▲ 5223	● 526	---
Particles >14µm		ASTM D7647	>160	22	● 23	---
Particles >21µm		ASTM D7647	>40	7	● 7	---
Particles >38µm		ASTM D7647	>10	1	● 0	---
Particles >71µm		ASTM D7647	>3	0	● 0	---
Oil Cleanliness		ISO 4406 (c)	>19/17/14	▲ 23/20/12	● 20/16/12	---

FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.37	0.41	0.249	---


OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	---
Silt	scalar	*Visual	NONE	NONE	---
Debris	scalar	*Visual	NONE	NONE	---
Sand/Dirt	scalar	*Visual	NONE	NONE	---
Appearance	scalar	*Visual	NORML	NORML	---
Odor	scalar	*Visual	NORML	NORML	---
Emulsified Water	scalar	*Visual	>0.05	NEG	---
Free Water	scalar	*Visual		NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	69.43	41.17	66.3

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : RP0042949
Lab Number : 06133296
Unique Number : 10952761
Test Package : IND 2
Received : 29 Mar 2024
Tested : 05 Apr 2024
Diagnosed : 05 Apr 2024 - Jonathan Hester

TEAM SUR S.A.S.
 BOGOTA,
 CO
 Contact: Team Sur
 jconde@teamsur.com
 T: (300)740-0654
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)