

OIL ANALYSIS REPORT

Sample Rating Trend

ISO

KAESER 7336545

Compressor Fluid KAESER SIGMA (OEM) S-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. The filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is acceptable for the time in service.

			Apr2023	Jan2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC06133322	KC101380	
Sample Date		Client Info		17 Jan 2024	26 Apr 2023	
Machine Age	hrs	Client Info		26530	21824	
Oil Age	hrs	Client Info		0	4864	
Oil Changed		Client Info		N/A	Changed	
Sample Status				ABNORMAL	NORMAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	
Chromium	ppm	ASTM D5185m	>10	<1	<1	
Nickel	ppm	ASTM D5185m	>3	0	<1	
Titanium	ppm	ASTM D5185m	>3	<1	0	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	3	<1	
Lead	ppm	ASTM D5185m	>10	<1	0	
Copper	ppm	ASTM D5185m	>50	9	16	
Tin	ppm	ASTM D5185m	>10	<1	0	
Vanadium	ppm	ASTM D5185m	_	<1	0	
Cadmium	ppm	ASTM D5185m		<1	0	
ADDITIVES	ppin	method	limit/base		-	history2
			inniv base	current	history1	nistory2
Boron	ppm	ASTM D5185m		0	0	
Barium	ppm	ASTM D5185m	90	11	0	
Molybdenum	ppm	ASTM D5185m		0	0	
Manganese	ppm	ASTM D5185m		0	<1	
Magnesium	ppm	ASTM D5185m	90	19	<1	
Calcium	ppm	ASTM D5185m	2	3	0	
Phosphorus	ppm	ASTM D5185m		0	0	
Zinc	ppm	ASTM D5185m		26	8	
CONTAMINANTS	6	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	0	
Sodium	ppm	ASTM D5185m		4	1	
Potassium	ppm	ASTM D5185m	>20	2	3	
Water	%	ASTM D6304	>0.05	0.011	0.003	
ppm Water	ppm	ASTM D6304	>500	115	27.1	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		17589	2644	
Particles >6µm		ASTM D7647	>1300	<u> </u>	787	
Particles >14µm		ASTM D7647	>80	A 326	59	
Particles >21µm		ASTM D7647	>20	<u> </u>	16	
Particles >38µm		ASTM D7647	>4	1	0	
Particles >71µm		ASTM D7647	>3	0	0	
Oil Cleanliness		ISO 4406 (c)	>/17/13	A 21/20/16	19/17/13	
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.33	0.26	



OIL ANALYSIS REPORT

scalar

scalar

scalar

scalar

scalar

scalar

scalar

scalar

method

*Visual

*Visual

*Visua

*Visual

*Visual

*Visual

*Visual

*Visual

scalar *Visual

scalar *Visual

limit/base

NONE

NONE

NONE

NONE

NONE

NONE

NORML

NORML

>0.05

current

NONE

NONE

NONE

NONE

NONE

NONE

NORML

NORML

NEG

NEG

history1

NONE

NONE

NONE

NONE

LIGHT

NONE

NORML

NORML

history

history1

NEG

NEG

44.2

history2

history


history2


no image

no image


4406

:1999 Cle





RF-



UNION PACIFIC - LIVONIA 2173 MARINGOUIN RD W LIVONIA, LA US 70757 Contact: Service Manager

214

28

Certificate 12367 Test Package : IND 2 To discuss this sample report, contact Customer Service at 1-800-237-1369.

: 06133322

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Tested

Diagnosed

:01 Apr 2024

: 01 Apr 2024 - Doug Bogart

Lab Number

Unique Number : 10952787

Contact/Location: Service Manager - UNILIV