

OIL ANALYSIS REPORT

Area **ATLAS COPCO API790594 - MICROSOFT** Component Compressor

Recommendation

Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.




NORMAL

SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UCH06133507		
Sample Date		Client Info		12 Mar 2024		
Machine Age	hrs	Client Info		849		
Oil Age	hrs	Client Info		404		
Oil Changed		Client Info		Changed		
Sample Status				NORMAL		
CONTAMINATIO	N	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0		
Chromium	ppm	ASTM D5185m	>5	<1		
Nickel	ppm	ASTM D5185m		<1		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>15	<1		
Lead	ppm	ASTM D5185m	>65	0		
Copper	ppm	ASTM D5185m	>65	0		
Tin	ppm	ASTM D5185m	>10	0		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m		0		
Calcium	ppm	ASTM D5185m		0		
Phosphorus	ppm	ASTM D5185m		97		
Zinc	ppm	ASTM D5185m		0		
Sulfur	ppm	ASTM D5185m		622		
CONTAMINANTS	5	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>35	0		
Sodium	ppm	ASTM D5185m		<1		
Potassium	ppm	ASTM D5185m	>20	<1		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.16		



OIL ANALYSIS REPORT



	VISUAL		method	limit/base	current	history1	history2
	White Metal	scalar	*Visual	NONE	NONE		
	Yellow Metal	scalar	*Visual	NONE	NONE		
	Precipitate	scalar	*Visual	NONE	NONE		
	Silt	scalar	*Visual	NONE	NONE		
	Debris	scalar	*Visual	NONE	NONE		
	Sand/Dirt	scalar	*Visual	NONE	NONE		
Marl 2/24	Appearance	scalar	*Visual	NORML	NORML		
Wa	Odor	scalar	*Visual	NORML	NORML		
	Emulsified Water	scalar	*Visual	>0.1	NEG		
	Free Water	scalar	*Visual		NEG		
	FLUID PROPERT	IES	method	limit/base	current	history1	history2
	Visc @ 40°C	cSt	ASTM D445		70.6		
	SAMPLE IMAGES	6	method	limit/base	current	history1	history2
Mar12/24	Color					no image	no image
	Bottom					no image	no image
	Ferrous Alloys	s		Mar1224			
	udd 6 - tin 2 - tin 2 - tin 5272 Law			Mar12/24			
	≥ Viscosity @ 40°C			2	Acid Number		
	80 70 (0,60 40 30 + 50 50 Abnormal 0 0 + 50 50 0 0 0 0 0 0 0 0 0 0 0 0 0 0			Mari 2224	4Cid Number		
Laboratory Sample No. Lab Number Unique Number Test Package iscuss this sample report,	: WearCheck USA - 50 : UCH06133507 : 06133507 : 10952972 : IND 2	1 Madison Ave., Cary, NC 27513 Received : 29 Mar 2024 Tested : 01 Apr 2024 Diagnosed : 03 Apr 2024 - Jonathan Hester <i>ice at 1-800-237-1369.</i> 7025 scope of accreditation.			CISCO AIR SYSTEM 214 27TH S SACRAMENTO, C US 9581 Contact: BARRY FRKOVIC barryfrkovich@ciscoair.co T: (916)444-252		

Contact/Location: BARRY FRKOVICH - UCCISSAC Page 2 of 2