

OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL

Area PNEUTECH PG-46 [281617] Machine to INGERSOLL RAND NC0716U08252 - KBS111 Component

Component Compressor

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor. Please specify the brand, type, and viscosity of the oil on your next sample.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition


The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

				Mar2024		
SAMPLE INFORM	IATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UFD0000675		
Sample Date		Client Info		19 Mar 2024		
Machine Age	hrs	Client Info		28604		
Oil Age	hrs	Client Info		28604		
Oil Changed		Client Info		Changed		
Sample Status				NORMAL		
CONTAMINATIO	N	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0		
Chromium	ppm	ASTM D5185m	>10	<1		
Nickel	ppm	ASTM D5185m		<1		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>25	<1		
Lead	ppm	ASTM D5185m	>25	0		
Copper	ppm	ASTM D5185m	>50	0		
Tin	ppm	ASTM D5185m	>15	0		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m		0		
Calcium	ppm	ASTM D5185m		0		
Phosphorus	ppm	ASTM D5185m		327		
Zinc	ppm	ASTM D5185m		0		
Sulfur	ppm	ASTM D5185m		0		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0		
Sodium	ppm	ASTM D5185m		1		
Potassium	ppm	ASTM D5185m	>20	<1		
FLUID DEGRADA		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.21		



OIL ANALYSIS REPORT

VISUAL



			method			history1	history2
	White Metal	scalar	*Visual	NONE	NONE		
	Yellow Metal	scalar	*Visual	NONE	NONE		
	Precipitate	scalar	*Visual	NONE	NONE		
	Silt	scalar	*Visual	NONE	NONE		
	Debris	scalar	*Visual	NONE	NONE		
	Sand/Dirt	scalar	*Visual	NONE	NONE		
Mar19,24	Appearance	scalar	*Visual	NORML	NORML		
Marl	Odor	scalar	*Visual	NORML	NORML		
	Emulsified Water	scalar	*Visual	>0.1	NEG		
	Free Water	scalar	*Visual		NEG		
	FLUID PROPER	TIFS	method	limit/base	current	history1	history2
	Visc @ 40°C	cSt	ASTM D445	intit/base	47.1	mistory	
	_						
	SAMPLE IMAGE	ES	method	limit/base	current	history1	history2
Mar1 9/24 +	Color				•	no image	no image
	Bottom					no image	no image
	Non-ferrous Meta			Mar19/24			
	Non-ferrous Meta						
	Non-ferrous Meta	als		Mar19/24 Mar19/24	Acid Number		
	Non-ferrous Meta Non-ferrous Meta lad und 2 Viscosity @ 40°C	als		Mar1924 Acid Number (ng KOH(g) 5000 5000 5000 5000 5000 5000 5000 50			
	Non-ferrous Meta Non-ferrous Meta log bead Non-ferrous Meta log bead Viscosity @ 40°C	als		Mar19/24 5200 5000 1000 1001 100 100 100 100 100 10			
Laboratory Sample No. Lab Number Unique Number Test Package	Non-ferrous Meta Non-ferrous	als 01 Madiso Recei Teste	on Ave., Cary ived : 29	Mar19/24 Mar19/24 Mar19/24 Mar19/24 Mar19/24 Mar19/24 Mar19/24	Flags	BU	

Ē

Contact/Location: Service Manager - UCFLUBUR Page 2 of 2