

OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL

Area NOT GIVEN [271848] PNEUTECH AK1000150083

Component Compressor

DIAGNOSIS

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


SAMPLE INFORM	NATION	method	limit/base	current	history1	history2
Sample Number		Client Info		UFD0000683		
Sample Date		Client Info		28 Mar 2024		
Machine Age	hrs	Client Info		0		
Oil Age	hrs	Client Info		500		
Oil Changed		Client Info		Changed		
Sample Status				NORMAL		
CONTAMINATIO	N	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0		
Chromium	ppm	ASTM D5185m	>10	<1		
Nickel	ppm	ASTM D5185m		<1		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>25	<1		
Lead	ppm	ASTM D5185m	>25	0		
Copper	ppm	ASTM D5185m	>50	0		
Tin	ppm	ASTM D5185m	>15	0		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m		0		
Calcium	ppm	ASTM D5185m		0		
Phosphorus	ppm	ASTM D5185m		336		
Zinc	ppm	ASTM D5185m		0		
Sulfur	ppm	ASTM D5185m		264		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1		
Sodium	ppm	ASTM D5185m		0		
Potassium	ppm	ASTM D5185m	>20	<1		
FLUID DEGRADA		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.19		

Report Id: UCFLUBUR [WUSCAR] 06133529 (Generated: 04/03/2024 16:07:57) Rev: 1



OIL ANALYSIS REPORT

VISUAL



Laboratory Sample No. Lab Number Unique Number Test Package	: 10952994	501 Madison Receive Tested Diagno	ed : 29 : 01	NC 27513 Mar 2024 Apr 2024 Apr 2024 - Don		FLUID-AIRE DYNAMICS - (MN 14250 JUDICIAL ROA BURNSVILLE, MI US 5530 Contact: Service Manage	
	Viscosity @ 40°C	C		Mar28/24 Acid Number (mg K0H/g) 0000 Acid Number (mg K0H/g)	Acid Number		ACC
	Non-ferrous Met			Mar28/24			
	GRAPHS Ferrous Alloys						
Mad	Bottom					no image	no image
Mar28/24 +	SAMPLE IMAGE	ES	method	limit/base	current	history1 no image	history2 no image
	FLUID PROPEF Visc @ 40°C		method ASTM D445	limit/base	current 45.0	history1	history2
 	Free Water	scalar *	Visual		NEG		
Mar	Odor Emulsified Water			NORML >0.1	NORML NEG		
Mar28/24 -	Appearance			NORML	NORML		
	Sand/Dirt			NONE	NONE		
	Silt Debris			NONE NONE	NONE NONE		
	Precipitate			NONE	NONE		
	Yellow Metal	scalar *	Visual	NONE	NONE		

Contact/Location: Service Manager - UCFLUBUR Page 2 of 2