

OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL

Area **PG-46** [278947] PNEUTECH AK100020407 - BLUE Component Compressor

Recommendation

Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


				Mar2024		
SAMPLE INFORM	ΛΑΤΙΟΝ	method	limit/base	current	history1	history2
Sample Number		Client Info		UFD0000238		
Sample Date		Client Info		28 Mar 2024		
Machine Age	hrs	Client Info		468		
Oil Age	hrs	Client Info		0		
Oil Changed		Client Info		Changed		
Sample Status				NORMAL		
CONTAMINATION		method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0		
Chromium	ppm	ASTM D5185m	>10	<1		
Nickel	ppm	ASTM D5185m		<1		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>25	<1		
Lead	ppm	ASTM D5185m	>25	0		
Copper	ppm	ASTM D5185m	>50	0		
Tin	ppm	ASTM D5185m	>15	0		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		0		
Manganese	ppm	ASTM D5185m		0		
Magnesium	ppm	ASTM D5185m		0		
Calcium	ppm	ASTM D5185m		0		
Phosphorus	ppm	ASTM D5185m		22		
Zinc	ppm	ASTM D5185m		0		
Sulfur	ppm	ASTM D5185m		197		
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	17		
Sodium	ppm	ASTM D5185m		<1		
Potassium	ppm	ASTM D5185m	>20	<1		
FLUID DEGRADA		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.079		





OIL ANALYSIS REPORT

VISUAL



	VISUAL		method			history1	history2
	White Metal	scalar	*Visual	NONE	NONE		
	Yellow Metal	scalar	*Visual	NONE	NONE		
	Precipitate	scalar	*Visual	NONE	NONE		
	Silt		*Visual	NONE	NONE		
	Debris	scalar	*Visual	NONE	NONE		
	Sand/Dirt	scalar	*Visual	NONE	NONE		
8/24 -	Appearance	scalar	*Visual	NORML	NORML		
Mar28/24	Odor		*Visual	NORML	NORML		
	Emulsified Water	scalar	*Visual	>0.1	NEG		
	Free Water	scalar	*Visual		NEG		
				line it //e e e e		late to met	histow O
	FLUID PROPERT		method	limit/base	current	history1	history2
	Visc @ 40°C	cSt	ASTM D445		43.7		
	SAMPLE IMAGES	5	method	limit/base	current	history1	history2
Mar28/24 +	Color					no image	no image
	Bottom					no image	no image
	Non-ferrous Metal			Mar28/24	Acid Numbe	r	
	55 Abnormal					r	
	20			8/24 Acid Number (mg KOH/g) 000 for (mg KOH/g)	U		104
	Mar28/24			Mar28/24	Mar28/24		Mar28/24
				NO 07540			
Laboratory Sample No. Lab Number Unique Number Test Package discuss this sample report.	: 10952996 : IND 2	Receiv Testec Diagno	ved : 29 I : 03 osed : 03	9 Mar 2024 8 Apr 2024 Apr 2024 - Don		14250 JI BU	NAMICS - (MN) JDICIAL ROAE RNSVILLE, MN US 55306 ervice Manage

Contact/Location: Service Manager - UCFLUBUR Page 2 of 2