




FUEL REPORT

Sample Rating Trend



WATER



Machine Id
TOSHIBA 3

Component
Diesel Fuel

Fluid
No.2 DIESEL FUEL (HIGH-SULPHUR) (--- GAL)

DIAGNOSIS

Recommendation

We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid.

Corrosion

All metal levels are normal indicating no corrosion in the system.

Contaminants

There is a high amount of particulates present in the fuel. Free water present. There is a moderate amount of visible silt present in the sample. There is no bacteria or fungus (yeast and/or mold) present in the sample.

Fuel Condition

Sulfur value derived by ASTM D5453 method for ULSD validation.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			WC06133766	WC05213702	WC04933048
Sample Date	Client Info			28 Mar 2024	24 Mar 2021	12 Mar 2020
Machine Age	hrs	Client Info		0	0	0
Sample Status				ABNORMAL	NORMAL	NORMAL

PHYSICAL PROPERTIES		method	limit/base	current	history1	history2
Specific Gravity		*ASTM D1298	0.839	---	0.849	0.849
Fuel Color	text	*Visual Screen	Yllow	Red	Red	Red
ASTM Color	scalar	*ASTM D1500		L4.0	L5.5	L6.0
Visc @ 40°C	cSt	ASTM D445	3.0	2.46	2.58	2.56
Pensky-Martens Flash Point	°C	*PMCC Calculated	52	62.1	64	64

SULFUR CONTENT		method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m	500	305	567	594
Sulfur (UVF)	ppm	ASTM D5453		394	560	526






DISTILLATION		method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D86	165	173	164	159
5% Distillation Point	°C	ASTM D86		197	195	191
10% Distill Point	°C	ASTM D86	201	207	207	204
15% Distillation Point	°C	ASTM D86		215	216	214
20% Distill Point	°C	ASTM D86	216	223	223	222
30% Distill Point	°C	ASTM D86	230	238	237	237
40% Distill Point	°C	ASTM D86	243	250	250	250
50% Distill Point	°C	ASTM D86	255	263	262	262
60% Distill Point	°C	ASTM D86	267	276	275	274
70% Distill Point	°C	ASTM D86	280	289	288	287
80% Distill Point	°C	ASTM D86	295	303	303	302
85% Distillation Point	°C	ASTM D86		313	312	310
90% Distill Point	°C	ASTM D86	310	323	322	321
95% Distillation Point	°C	ASTM D86		340	340	336
Final Boiling Point	°C	ASTM D86	341	354	346	346
Distillation Residue	%	ASTM D86	3.0	---	1.4	1.4
Distillation Loss	%	ASTM D86	3.0	---	0.5	0.1

IGNITION QUALITY		method	limit/base	current	history1	history2
API Gravity		ASTM D7777	37.7	35	35.2	35.2
Cetane Index		ASTM D4737	<40.0	46	43.7	43.2

CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	<1	<1	<1
Sodium	ppm	ASTM D5185m	<0.1	0	<1	0
Potassium	ppm	ASTM D5185m	<0.1	1	1	0
Water	%	ASTM D6304	<0.05	0.004	0.005	0.004
ppm Water	ppm	ASTM D6304	<500	40	56.8	44.4
% Gasoline	%	*In-House	<0.50	0.0	0.0	0.0
% Biodiesel	%	*In-House	<20.0	0.0	0.0	0.0



FUEL REPORT



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : WC06133766
Lab Number : 06133766
Unique Number : 10953231
Test Package : DF-2 (Additional Tests: Bacteria, Fuel, Screen)
Received : 29 Mar 2024
Tested : 11 Apr 2024
Diagnosed : 11 Apr 2024 - Doug Bogart



COUCH OIL COMPANY
 2907 HILLSBOROUGH RD
 DURHAM, NC
 US 27705
 Contact: JESSE BROWN
 jesse@couchoilcompany.com
 T: (919)285-5408
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>2500	▲ 14067	---	---
Particles >6µm	ASTM D7647	>640	▲ 3237	---	---
Particles >14µm	ASTM D7647	>80	▲ 119	---	---
Particles >21µm	ASTM D7647	>20	▲ 23	---	---
Particles >38µm	ASTM D7647	>4	1	---	---
Particles >71µm	ASTM D7647	>3	0	---	---
Oil Cleanliness	ISO 4406 (c)	>18/16/13	▲ 21/19/14	---	---

MICROBIAL	method	limit/base	current	history1	history2
Bacteria	CFU/ml WC-Method	>=100000	0	---	---
Yeast	CFU/ml WC-Method	>=100000	0	---	---
Mold	Colonies WC-Method	MODER	---	---	---

HEAVY METALS	method	limit/base	current	history1	history2
Aluminum	ppm ASTM D5185m	<0.1	0	0	0
Nickel	ppm ASTM D5185m	<0.1	0	<1	<1
Lead	ppm ASTM D5185m	<0.1	0	<1	0
Vanadium	ppm ASTM D5185m	<0.1	0	0	<1
Iron	ppm ASTM D5185m	<0.1	0	0	0
Calcium	ppm ASTM D5185m	<0.1	4	<1	<1
Magnesium	ppm ASTM D5185m	<0.1	<1	<1	<1
Phosphorus	ppm ASTM D5185m	<0.1	0	0	0
Zinc	ppm ASTM D5185m	<0.1	0	<1	0

SAMPLE IMAGES	method	limit/base	current	history1	history2	
Color					no image	no image
Bottom					no image	no image