


# OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Machine Id  
**7497073 (S/N 1293)**

Component  
**Compressor**  
Fluid  
**KAESER SIGMA (OEM) M-460 (--- GAL)**

**DIAGNOSIS**

▲ **Recommendation**

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

**Wear**

All component wear rates are normal.

▲ **Contamination**

There is a high amount of particulates present in the oil.

**Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

**SAMPLE INFORMATION**

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>KCPA013925</b>	KCPA001588	KCP48709
Sample Date	Client Info	<b>27 Mar 2024</b>	22 Mar 2023	16 Feb 2022
Machine Age	hrs	<b>15848</b>	11422	7030
Oil Age	hrs	<b>4000</b>	0	7030
Oil Changed	Client Info	<b>Changed</b>	N/A	Changed
Sample Status		<b>ABNORMAL</b>	ABNORMAL	ABNORMAL

**WEAR METALS**

method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m >50	<b>&lt;1</b>	<1	<1
Chromium	ppm	ASTM D5185m >10	<b>0</b>	0	0
Nickel	ppm	ASTM D5185m >3	<b>0</b>	<1	0
Titanium	ppm	ASTM D5185m >3	<b>0</b>	0	0
Silver	ppm	ASTM D5185m >2	<b>0</b>	0	0
Aluminum	ppm	ASTM D5185m >10	<b>0</b>	<1	0
Lead	ppm	ASTM D5185m >10	<b>0</b>	0	0
Copper	ppm	ASTM D5185m >50	<b>6</b>	11	19
Tin	ppm	ASTM D5185m >10	<b>0</b>	0	0
Antimony	ppm	ASTM D5185m	<b>---</b>	---	0
Vanadium	ppm	ASTM D5185m	<b>&lt;1</b>	0	0
Cadmium	ppm	ASTM D5185m	<b>0</b>	0	0

**ADDITIVES**

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m 0	<b>0</b>	0	<1
Barium	ppm	ASTM D5185m 90	<b>15</b>	0	0
Molybdenum	ppm	ASTM D5185m 0	<b>0</b>	0	0
Manganese	ppm	ASTM D5185m	<b>0</b>	0	0
Magnesium	ppm	ASTM D5185m 100	<b>62</b>	20	8
Calcium	ppm	ASTM D5185m 0	<b>1</b>	0	0
Phosphorus	ppm	ASTM D5185m 0	<b>2</b>	2	7
Zinc	ppm	ASTM D5185m 0	<b>8</b>	13	12
Sulfur	ppm	ASTM D5185m 23500	<b>21679</b>	23110	13345

**CONTAMINANTS**

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m >25	<b>&lt;1</b>	<1	<1
Sodium	ppm	ASTM D5185m	<b>33</b>	8	2
Potassium	ppm	ASTM D5185m >20	<b>14</b>	3	0
Water	%	ASTM D6304 >0.05	<b>0.011</b>	0.008	0.006
ppm Water	ppm	ASTM D6304 >500	<b>117</b>	88.6	61.1






**FLUID CLEANLINESS**

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	<b>12182</b>	22521	32305
Particles >6µm	ASTM D7647 >1300	▲ <b>5027</b>	▲ 9087	▲ 13092
Particles >14µm	ASTM D7647 >80	▲ <b>325</b>	▲ 83	▲ 178
Particles >21µm	ASTM D7647 >20	▲ <b>68</b>	4	13
Particles >38µm	ASTM D7647 >4	<b>1</b>	1	1
Particles >71µm	ASTM D7647 >3	<b>0</b>	1	0
Oil Cleanliness	ISO 4406 (c) >--/17/13	▲ <b>21/20/16</b>	▲ 22/20/14	▲ 21/15

**FLUID DEGRADATION**

method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045 1.0	<b>0.46</b>	0.35	0.36


# OIL ANALYSIS REPORT







PARAMETER	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	45	52.6	50.9

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : KCPA013925 **Received** : 29 Mar 2024  
**Lab Number** : 06134023 **Tested** : 03 Apr 2024  
**Unique Number** : 10953488 **Diagnosed** : 03 Apr 2024 - Don Baldrige  
**Test Package** : IND 2 ( Additional Tests: KF, PrtCount )

**DIGICAN PRINTING**  
 501 FOUNTAIN LAKES BLVD, SUITE 101  
 ST CHARLES, MO  
 US 63301  
 Contact: MARK S.  
 marks@digicanprinting.com  
 T:  
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)