




OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id
KAESER AIRCENTER SX5 4571865 (S/N 1136)

Component
Compressor
Fluid
KAESER SIGMA (OEM) S-460 (--- QTS)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	KCPA015965	KCP29320	KCP20265
Sample Date	Client Info	22 Mar 2024	22 Oct 2020	27 Nov 2019
Machine Age	hrs	9298	8226	7555
Oil Age	hrs	196	671	548
Oil Changed	Client Info	Changed	Changed	Not Changed
Sample Status		ABNORMAL	ABNORMAL	NORMAL

WEAR METALS

method	limit/base	current	history1	history2	
Iron	ppm	ASTM D5185m >50	<1	0	<1
Chromium	ppm	ASTM D5185m >10	0	0	0
Nickel	ppm	ASTM D5185m >3	0	0	0
Titanium	ppm	ASTM D5185m >3	0	0	0
Silver	ppm	ASTM D5185m >2	0	<1	<1
Aluminum	ppm	ASTM D5185m >10	0	0	<1
Lead	ppm	ASTM D5185m >10	0	0	<1
Copper	ppm	ASTM D5185m >50	2	6	4
Tin	ppm	ASTM D5185m >10	0	0	2
Antimony	ppm	ASTM D5185m	---	0	4
Vanadium	ppm	ASTM D5185m	<1	0	0
Cadmium	ppm	ASTM D5185m	0	0	0

ADDITIVES

method	limit/base	current	history1	history2	
Boron	ppm	ASTM D5185m	0	10	<1
Barium	ppm	ASTM D5185m 90	1	0	0
Molybdenum	ppm	ASTM D5185m	0	0	<1
Manganese	ppm	ASTM D5185m	0	0	<1
Magnesium	ppm	ASTM D5185m 90	51	14	15
Calcium	ppm	ASTM D5185m 2	24	0	0
Phosphorus	ppm	ASTM D5185m	0	2	0
Zinc	ppm	ASTM D5185m	27	53	53
Sulfur	ppm	ASTM D5185m	20351	15464	5194

CONTAMINANTS

method	limit/base	current	history1	history2	
Silicon	ppm	ASTM D5185m >25	<1	0	0
Sodium	ppm	ASTM D5185m	23	32	31
Potassium	ppm	ASTM D5185m >20	3	6	5
Water	%	ASTM D6304 >0.05	0.017	0.007	0.009
ppm Water	ppm	ASTM D6304 >500	177	75.8	92.4






FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	43084	10853	2382
Particles >6µm	ASTM D7647 >1300	▲ 13352	▲ 5199	638
Particles >14µm	ASTM D7647 >80	▲ 777	▲ 1183	61
Particles >21µm	ASTM D7647 >20	▲ 178	▲ 539	22
Particles >38µm	ASTM D7647 >4	▲ 6	▲ 48	1
Particles >71µm	ASTM D7647 >3	▲ 0	▲ 2	0
Oil Cleanliness	ISO 4406 (c) >--/17/13	▲ 23/21/17	▲ 20/17	16/13

FLUID DEGRADATION

method	limit/base	current	history1	history2	
Acid Number (AN)	mg KOH/g	ASTM D8045 0.4	0.31	0.169	0.147

OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	LIGHT	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 46	44.4	43.4	43.6

SAMPLE IMAGES

method	limit/base	current	history1	history2
Color				
Bottom				

GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KCPA015965 **Received** : 29 Mar 2024
Lab Number : 06134048 **Tested** : 01 Apr 2024
Unique Number : 10953513 **Diagnosed** : 03 Apr 2024 - Don Baldrige
Test Package : IND 2 (Additional Tests: KF, PrtCount)

OLD DOMINION FREIGHT LINE
 2921 DAWSON RD
 TULSA, OK
 US 74110
 Contact: JEREMY GILSON
 jeremy.gilson@odfl.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)