




OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id
KAESER SM 10 4578874 (S/N 1391)

Component
Compressor
Fluid
KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

We recommend you service the filters on this component. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	KCPA013536	KCP34871	KCP29950
Sample Date	Client Info	21 Mar 2024	11 Feb 2022	15 Dec 2020
Machine Age	hrs	17165	16119	15124
Oil Age	hrs	0	995	1494
Oil Changed	Client Info	N/A	Changed	Changed
Sample Status		ABNORMAL	NORMAL	ABNORMAL

WEAR METALS

method	limit/base	current	history1	history2
Iron ppm	ASTM D5185m >50	<1	1	1
Chromium ppm	ASTM D5185m >10	0	0	0
Nickel ppm	ASTM D5185m >3	0	<1	0
Titanium ppm	ASTM D5185m >3	0	0	0
Silver ppm	ASTM D5185m >2	0	0	<1
Aluminum ppm	ASTM D5185m >10	0	<1	0
Lead ppm	ASTM D5185m >10	0	0	<1
Copper ppm	ASTM D5185m >50	2	2	2
Tin ppm	ASTM D5185m >10	0	0	0
Antimony ppm	ASTM D5185m	---	0	0
Vanadium ppm	ASTM D5185m	<1	0	0
Cadmium ppm	ASTM D5185m	0	0	0

ADDITIVES

method	limit/base	current	history1	history2
Boron ppm	ASTM D5185m 0	0	0	<1
Barium ppm	ASTM D5185m 90	<1	0	<1
Molybdenum ppm	ASTM D5185m 0	0	0	0
Manganese ppm	ASTM D5185m	0	<1	<1
Magnesium ppm	ASTM D5185m 100	32	61	45
Calcium ppm	ASTM D5185m 0	<1	1	1
Phosphorus ppm	ASTM D5185m 0	0	11	4
Zinc ppm	ASTM D5185m 0	42	45	63
Sulfur ppm	ASTM D5185m 23500	20819	18344	18298

CONTAMINANTS

method	limit/base	current	history1	history2
Silicon ppm	ASTM D5185m >25	1	1	3
Sodium ppm	ASTM D5185m	15	18	6
Potassium ppm	ASTM D5185m >20	2	2	2
Water %	ASTM D6304 >0.05	0.031	0.012	▲ 0.169
ppm Water	ASTM D6304 >500	320	121.8	▲ 1690






FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	5799	2481	---
Particles >6µm	ASTM D7647 >1300	▲ 2196	538	---
Particles >14µm	ASTM D7647 >80	▲ 290	36	---
Particles >21µm	ASTM D7647 >20	▲ 94	10	---
Particles >38µm	ASTM D7647 >4	▲ 5	0	---
Particles >71µm	ASTM D7647 >3	0	0	---
Oil Cleanliness	ISO 4406 (c) >--/17/13	▲ 20/18/15	16/12	---

FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN) mg KOH/g	ASTM D8045 1.0	0.32	0.30	0.378


OIL ANALYSIS REPORT








VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	LIGHT	▲ MODER
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	● HAZY
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	▲ 0.2%
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	45	44.9	45.6

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KCPA013536 **Received** : 29 Mar 2024
Lab Number : 06134049 **Tested** : 01 Apr 2024
Unique Number : 10953514 **Diagnosed** : 03 Apr 2024 - Don Baldrige
Test Package : IND 2 (Additional Tests: KF, PrtCount)

INSIGNIA SIGNS
 809 SE 83RD ST
 OKLAHOMA CITY, OK
 US 73149
 Contact: BRET
 bret@insigniasigns.com
 T:
 F:

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)