



# OIL ANALYSIS REPORT

Sample Rating Trend



ISO



Machine Id

**8291190 (S/N 1745)**

Component

**Compressor**

Fluid

**KAESER SIGMA (OEM) S-460 (--- GAL)**

## DIAGNOSIS

### Recommendation

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

### Wear

All component wear rates are normal.

### Contamination

There is a high amount of particulates present in the oil.

### Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

## SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	<b>KC130476</b>	---	---
Sample Date	Client Info	<b>21 Mar 2024</b>	---	---
Machine Age	hrs Client Info	<b>5135</b>	---	---
Oil Age	hrs Client Info	<b>3500</b>	---	---
Oil Changed	Client Info	<b>Changed</b>	---	---
Sample Status		<b>ABNORMAL</b>	---	---

## WEAR METALS

method	limit/base	current	history1	history2
Iron ppm	ASTM D5185m >50	<b>0</b>	---	---
Chromium ppm	ASTM D5185m >10	<b>0</b>	---	---
Nickel ppm	ASTM D5185m >3	<b>0</b>	---	---
Titanium ppm	ASTM D5185m >3	<b>0</b>	---	---
Silver ppm	ASTM D5185m >2	<b>0</b>	---	---
Aluminum ppm	ASTM D5185m >10	<b>&lt;1</b>	---	---
Lead ppm	ASTM D5185m >10	<b>0</b>	---	---
Copper ppm	ASTM D5185m >50	<b>6</b>	---	---
Tin ppm	ASTM D5185m >10	<b>0</b>	---	---
Vanadium ppm	ASTM D5185m	<b>&lt;1</b>	---	---
Cadmium ppm	ASTM D5185m	<b>0</b>	---	---

## ADDITIVES

method	limit/base	current	history1	history2
Boron ppm	ASTM D5185m	<b>0</b>	---	---
Barium ppm	ASTM D5185m 90	<b>4</b>	---	---
Molybdenum ppm	ASTM D5185m	<b>0</b>	---	---
Manganese ppm	ASTM D5185m	<b>0</b>	---	---
Magnesium ppm	ASTM D5185m 90	<b>27</b>	---	---
Calcium ppm	ASTM D5185m 2	<b>&lt;1</b>	---	---
Phosphorus ppm	ASTM D5185m	<b>0</b>	---	---
Zinc ppm	ASTM D5185m	<b>6</b>	---	---

## CONTAMINANTS

method	limit/base	current	history1	history2
Silicon ppm	ASTM D5185m >25	<b>&lt;1</b>	---	---
Sodium ppm	ASTM D5185m	<b>9</b>	---	---
Potassium ppm	ASTM D5185m >20	<b>4</b>	---	---
Water %	ASTM D6304 >0.05	<b>0.011</b>	---	---
ppm Water	ASTM D6304 >500	<b>117</b>	---	---






## FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	<b>4181</b>	---	---
Particles >6µm	ASTM D7647 >1300	<b>▲ 1587</b>	---	---
Particles >14µm	ASTM D7647 >80	<b>▲ 312</b>	---	---
Particles >21µm	ASTM D7647 >20	<b>▲ 151</b>	---	---
Particles >38µm	ASTM D7647 >4	<b>▲ 18</b>	---	---
Particles >71µm	ASTM D7647 >3	<b>1</b>	---	---
Oil Cleanliness	ISO 4406 (c) >--/17/13	<b>▲ 19/18/15</b>	---	---

## FLUID DEGRADATION

method	limit/base	current	history1	history2
Acid Number (AN) mg KOH/g	ASTM D8045 0.4	<b>0.35</b>	---	---

# OIL ANALYSIS REPORT







VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	---
Yellow Metal	scalar	*Visual	NONE	NONE	---
Precipitate	scalar	*Visual	NONE	NONE	---
Silt	scalar	*Visual	NONE	NONE	---
Debris	scalar	*Visual	NONE	NONE	---
Sand/Dirt	scalar	*Visual	NONE	NONE	---
Appearance	scalar	*Visual	NORML	NORML	---
Odor	scalar	*Visual	NORML	NORML	---
Emulsified Water	scalar	*Visual	>0.05	NEG	---
Free Water	scalar	*Visual		NEG	---

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	46	44.7	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------

Color		no image	no image
Bottom		no image	no image

## GRAPHS



**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : KC130476  
**Lab Number** : 06134053  
**Unique Number** : 10953518  
**Test Package** : IND 2  
**Received** : 29 Mar 2024  
**Tested** : 01 Apr 2024  
**Diagnosed** : 03 Apr 2024 - Don Baldrige

**SC TOOL**  
 720 MT PLEASANT RD  
 SPARTANBURG, SC  
 US 29307  
 Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.  
 \* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.  
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)