

OIL ANALYSIS REPORT

Sample Rating Trend

NORMAL

Machine Id

QUINCY 92484J - MCCALL FARMS

Compressor

ULTRACHEM PO 4010 (--- GAL)

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

There is no indication of any contamination in the

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


				Mar2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		WC0845241		
Sample Date		Client Info		26 Mar 2024		
Machine Age	hrs	Client Info		68345		
Oil Age	hrs	Client Info		2000		
Oil Changed		Client Info		Not Changd		
Sample Status				NORMAL		
CONTAMINATION	١	method	limit/base	current	history1	history2
Water		WC Method	>0.1	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1		
Chromium	ppm	ASTM D5185m	>10	0		
Nickel	ppm	ASTM D5185m		0		
Titanium	ppm	ASTM D5185m		0		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm	ASTM D5185m	>25	0		
Lead	ppm	ASTM D5185m	>25	0		
Copper	ppm	ASTM D5185m	>50	3		
Tin	ppm	ASTM D5185m	>15	0		
Vanadium	ppm	ASTM D5185m		0		
Cadmium	ppm	ASTM D5185m		0		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0		
Barium	ppm	ASTM D5185m	0.4	0		
Molybdenum	ppm	ASTM D5185m	0.5	0		
Manganese	ppm	ASTM D5185m	0.4	0		
Magnesium	ppm	ASTM D5185m	0	0		
Calcium	ppm	ASTM D5185m	0.3	0		
Phosphorus	ppm	ASTM D5185m	1376	580		
Zinc	ppm	ASTM D5185m	0	38		
Sulfur	ppm	ASTM D5185m	320	1132		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	1		
Sodium	ppm	ASTM D5185m		<1		
Potassium	ppm	ASTM D5185m	>20	<1		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2

0.21

Acid Number (AN) mg KOH/g ASTM D8045 0.573



OIL ANALYSIS REPORT





\/(Q\ \A\)						
VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE		
Yellow Metal	scalar	*Visual	NONE	NONE		
Precipitate	scalar	*Visual	NONE	NONE		
Silt	scalar	*Visual	NONE	NONE		
Debris	scalar	*Visual	NONE	NONE		
Sand/Dirt	scalar	*Visual	NONE	NONE		
Appearance	scalar	*Visual	NORML	NORML		
Odor	scalar	*Visual	NORML	NORML		
Emulsified Water	scalar	*Visual	>0.1	NEG		
Free Water	scalar	*Visual		NEG		
FLUID PROPERT	TES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	41.57	48.1		
SAMPLE IMAGES	3	method	limit/base	current	history1	history2
Color					no image	no image


GRAPHS

Bottom









no image

no image





Laboratory Sample No.

Test Package : IND 2

: WC0845241 Lab Number : 06134145 Unique Number : 10953610

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received **Tested**

: 29 Mar 2024 : 01 Apr 2024 Diagnosed : 03 Apr 2024 - Don Baldridge

ELEVATED INDUSTRIAL SOLUTIONS - EIS

302 HUGHES ST FOUNTAIN INN, SC US 29644

Contact: DARRIN WARD dward@elevatedindustrial.com

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: (864)862-7653