




OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Area

OCC AND PULP

Machine Id

423.0510 C-Blow Tank Agitator

Component

Agitator Gearbox

Fluid

SHELL MORLINA S4 B 460 (15 GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of silt (particulates < 6 microns in size) present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

method	limit/base	current	history1	history2
Sample Number	Client Info	PE0003956	PE0002926	PE0002994
Sample Date	Client Info	26 Mar 2024	05 Jan 2024	30 Nov 2023
Machine Age	hrs	0	0	0
Oil Age	hrs	0	0	0
Oil Changed	Client Info	N/A	Not Chngd	N/A
Sample Status		NORMAL	NORMAL	NORMAL

CONTAMINATION

method	limit/base	current	history1	history2
Water	WC Method >0.1	NEG	NEG	NEG

WEAR METALS

method	limit/base	current	history1	history2
PQ	ASTM D8184	19	11	16
Iron	ppm ASTM D5185m >150	3	5	0
Chromium	ppm ASTM D5185m >10	0	<1	0
Nickel	ppm ASTM D5185m >10	0	0	0
Titanium	ppm ASTM D5185m	0	<1	0
Silver	ppm ASTM D5185m	0	0	0
Aluminum	ppm ASTM D5185m >25	<1	2	0
Lead	ppm ASTM D5185m >100	0	0	0
Copper	ppm ASTM D5185m >50	4	4	2
Tin	ppm ASTM D5185m >10	0	<1	0
Vanadium	ppm ASTM D5185m	0	<1	0
Cadmium	ppm ASTM D5185m	0	0	0

ADDITIVES

method	limit/base	current	history1	history2
Boron	ppm ASTM D5185m	0	0	0
Barium	ppm ASTM D5185m	0	0	0
Molybdenum	ppm ASTM D5185m	0	0	0
Manganese	ppm ASTM D5185m	0	0	0
Magnesium	ppm ASTM D5185m	<1	0	<1
Calcium	ppm ASTM D5185m	19	9	1
Phosphorus	ppm ASTM D5185m	173	239	239
Zinc	ppm ASTM D5185m	14	0	0
Sulfur	ppm ASTM D5185m	650	691	578






CONTAMINANTS

method	limit/base	current	history1	history2
Silicon	ppm ASTM D5185m >50	3	5	3
Sodium	ppm ASTM D5185m	0	2	0
Potassium	ppm ASTM D5185m >20	2	1	0

FLUID CLEANLINESS

method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647 >20000	5398	12436	1053
Particles >6µm	ASTM D7647 >5000	1501	2035	316
Particles >14µm	ASTM D7647 >640	60	73	19
Particles >21µm	ASTM D7647 >160	9	16	6
Particles >38µm	ASTM D7647 >40	0	1	0
Particles >71µm	ASTM D7647 >10	0	1	0
Oil Cleanliness	ISO 4406 (c) >21/19/16	20/18/13	21/18/13	17/15/11

OIL ANALYSIS REPORT




FLUID DEGRADATION		method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045		0.37	0.43	0.56





VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	LIGHT	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.1	NEG	NEG	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG

FLUID PROPERTIES		method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	445	409	412	440

SAMPLE IMAGES		method	limit/base	current	history1	history2
---------------	--	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : PE0003956
Lab Number : 06134770
Unique Number : 10954235
Test Package : PLANT (Additional Tests: ICP, KV40, PQ, PrtCount, SCREEN)

Received : 01 Apr 2024
Tested : 02 Apr 2024
Diagnosed : 03 Apr 2024 - Don Baldrige

To discuss this sample report, contact Customer Service at 1-800-237-1369.
 * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.
 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Port Townsend Paper Corporation
 100 Mill Rd
 Port Townsend, WA
 US 98368
 Contact: LONNIE LOREE
 lonnie.loree@ptpc.com
 T: (907)738-6506
 F: