


# **OIL ANALYSIS REPORT**

Sample Rating Trend



Machine Id

# KAESER SX 7.5 4989714 (S/N 1082)

Component Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

### **DIAGNOSIS**

### Recommendation

Oil and filter change at the time of sampling has been noted. We recommend an early resample in 500 hours to monitor this condition.

All component wear rates are normal.

### Contamination

There is a moderate amount of particulates present in the oil. There is a light concentration of water present in the oil.


### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.


		Feb 2019 Ma				
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC129318	KC101796	KC85530
Sample Date		Client Info		20 Mar 2024	10 Apr 2023	12 Feb 2022
Machine Age	hrs	Client Info		22947	20951	20114
Oil Age	hrs	Client Info		1996	3000	6000
Oil Changed		Client Info		Changed	Changed	Changed
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	0	0	1
Chromium	ppm	ASTM D5185m	>10	0	0	0
Nickel	ppm	ASTM D5185m	>3	<1	0	0
Titanium	ppm	ASTM D5185m	>3	0	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m		0	<1	<1
Lead	ppm	ASTM D5185m	>10	0	0	0
Copper	ppm	ASTM D5185m	>50	<1	2	17
Tin	ppm	ASTM D5185m	>10	0	0	0
Antimony	ppm	ASTM D5185m				0
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		0	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	3
Barium	ppm	ASTM D5185m	90	5	<1	0
Molybdenum	ppm	ASTM D5185m		0	0	0
Manganese	ppm	ASTM D5185m		0	<1	0
Magnesium	ppm	ASTM D5185m	90	26	68	21
Calcium	ppm	ASTM D5185m	2	0	0	0
Phosphorus	ppm	ASTM D5185m		0	5	2
Zinc	ppm	ASTM D5185m		11	18	45
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	0	0	<1
Sodium	ppm	ASTM D5185m		4	16	10
Potassium	ppm	ASTM D5185m		3	0	0
Water	%	ASTM D6304		<b>△</b> 0.173	△ 0.050	0.011
ppm Water	ppm	ASTM D6304	>500	<u> </u>	▲ 502.7	117.7
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4μm		ASTM D7647		1192	36315	33966
Particles >6µm		ASTM D7647	>1300	649	<u>▲</u> 11047	<u> </u> 7414
Particles >14μm		ASTM D7647	>80	<u> </u>	<u>^</u> 280	<u></u> 316
Particles >21µm		ASTM D7647	>20	<b>9</b> 37	18	<u> </u>
Particles >38µm		ASTM D7647	>4	<u> </u>	1	1
Particles >71µm		ASTM D7647	>3	1	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	17/17/14	22/21/15	20/15
FLUID DEGRADA	TION	method	limit/base	current	history1	history2




## **OIL ANALYSIS REPORT**













Certificate 12367

Laboratory Sample No.

: KC129318 Lab Number : 06134911 Unique Number : 10954376 Test Package : IND 2

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 01 Apr 2024 **Tested** : 08 Apr 2024

Diagnosed

: 08 Apr 2024 - Jonathan Hester

Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

 $^st$  - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

**ENERGY PRODUCTS** 

LAWRENCE, PA

US 15055

T:

F:

400 COMMERCE BLVD