



# FUEL REPORT

Sample Rating Trend



CONTAMINANT



Machine Id  
**178658 - LENOX BAXER**

Component  
**Diesel Fuel**

Fluid  
**No.2 DIESEL FUEL (ULTRALOW SULPHUR) (--- QTS)**

## DIAGNOSIS

### Recommendation

We advise that you follow the water drain-off procedure for this component, and use off-line filtration to improve the cleanliness of the system fluid. We recommend you service and check the fuel filters for mucous-like deposits. Check with fuel supplier for biocides available to destroy the microorganisms in the fuel system.

### Corrosion

All metal levels are normal indicating no corrosion in the system.

### Contaminants

There is a high amount of particulates present in the fuel. There is a moderate amount of visible silt present in the sample. Excessive free water present. There is a moderate concentration of Bacteria, Yeast and/or Fungus present in the sample.

### Fuel Condition

Sulfur value derived by ASTM D5453 method for ULSD validation. Sulfur level is acceptable for ULSD specification.

## SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		<b>WC06135405</b>	---	---
Sample Date	Client Info		<b>29 Mar 2024</b>	---	---
Machine Age	hrs	Client Info	<b>0</b>	---	---
Sample Status			<b>ABNORMAL</b>	---	---

## PHYSICAL PROPERTIES

	method	limit/base	current	history1	history2
Fuel Color	text	*Visual Screen	Yellow	<b>Red</b>	---
ASTM Color	scalar	*ASTM D1500		<b>L4.0</b>	---
Visc @ 40°C	cSt	ASTM D445	3.0	<b>2.46</b>	---
Pensky-Martens Flash Point	°C	*PMCC Calculated	52	<b>60.9</b>	---

## SULFUR CONTENT

	method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m	10	<b>4</b>	---
Sulfur (UVF)	ppm	ASTM D5453		<b>9</b>	---

## DISTILLATION

	method	limit/base	current	history1	history2
Initial Boiling Point	°C	ASTM D86	165	<b>172</b>	---
5% Distillation Point	°C	ASTM D86		<b>195</b>	---
10% Distill Point	°C	ASTM D86	201	<b>205</b>	---
15% Distillation Point	°C	ASTM D86		<b>213</b>	---
20% Distill Point	°C	ASTM D86	216	<b>221</b>	---
30% Distill Point	°C	ASTM D86	230	<b>236</b>	---
40% Distill Point	°C	ASTM D86	243	<b>249</b>	---
50% Distill Point	°C	ASTM D86	255	<b>263</b>	---
60% Distill Point	°C	ASTM D86	267	<b>278</b>	---
70% Distill Point	°C	ASTM D86	280	<b>292</b>	---
80% Distill Point	°C	ASTM D86	295	<b>309</b>	---
85% Distillation Point	°C	ASTM D86		<b>319</b>	---
90% Distill Point	°C	ASTM D86	310	<b>329</b>	---
95% Distillation Point	°C	ASTM D86		<b>343</b>	---
Final Boiling Point	°C	ASTM D86	341	<b>357</b>	---

## IGNITION QUALITY






	method	limit/base	current	history1	history2
API Gravity	ASTM D7777	37.7	<b>36</b>	---	---
Cetane Index	ASTM D4737	<40.0	<b>48</b>	---	---

## CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	<b>&lt;1</b>	---
Sodium	ppm	ASTM D5185m	<0.1	<b>1</b>	---
Potassium	ppm	ASTM D5185m	<0.1	<b>0</b>	---
Water	%	ASTM D6304	<0.05	<b>0.020</b>	---
ppm Water	ppm	ASTM D6304	<500	<b>205</b>	---
% Gasoline	%	*In-House	<0.50	<b>0.0</b>	---
% Biodiesel	%	*In-House	<20.0	<b>3.0</b>	---



# FUEL REPORT



Certificate L2367

**Laboratory** : WearCheck USA - 501 Madison Ave., Cary, NC 27513  
**Sample No.** : WC06135405 **Received** : 01 Apr 2024  
**Lab Number** : 06135405 **Tested** : 11 Apr 2024  
**Unique Number** : 10954870 **Diagnosed** : 11 Apr 2024 - Doug Bogart  
**Test Package** : DF-2 ( Additional Tests: Bacteria, Fuel, Screen )

To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

**COUCH OIL COMPANY**  
 2907 HILLSBOROUGH RD  
 DURHAM, NC  
 US 27705  
 Contact: JESSE BROWN  
 jesse@couchoilcompany.com  
 T: (919)285-5408  
 F:

FLUID CLEANLINESS	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647	>2500	▲ 15227	---	---
Particles >6µm	ASTM D7647	>640	▲ 2504	---	---
Particles >14µm	ASTM D7647	>80	▲ 95	---	---
Particles >21µm	ASTM D7647	>20	▲ 21	---	---
Particles >38µm	ASTM D7647	>4	0	---	---
Particles >71µm	ASTM D7647	>3	0	---	---
Oil Cleanliness	ISO 4406 (c)	>18/16/13	▲ 21/19/14	---	---

MICROBIAL	method	limit/base	current	history1	history2
Bacteria	CFU/ml WC-Method	>=100000	▲ 100	---	---
Yeast	CFU/ml WC-Method	>=100000	▲ 10	---	---
Mold	Colonies WC-Method	MODER	---	---	---

HEAVY METALS	method	limit/base	current	history1	history2
Aluminum	ppm ASTM D5185m	<0.1	0	---	---
Nickel	ppm ASTM D5185m	<0.1	0	---	---
Lead	ppm ASTM D5185m	<0.1	0	---	---
Vanadium	ppm ASTM D5185m	<0.1	0	---	---
Iron	ppm ASTM D5185m	<0.1	<1	---	---
Calcium	ppm ASTM D5185m	<0.1	0	---	---
Magnesium	ppm ASTM D5185m	<0.1	0	---	---
Phosphorus	ppm ASTM D5185m	<0.1	0	---	---
Zinc	ppm ASTM D5185m	<0.1	0	---	---

SAMPLE IMAGES	method	limit/base	current	history1	history2
Color				no image	no image
Bottom				no image	no image

