

OIL ANALYSIS REPORT

Sample Rating Trend

ISO

Machine Id

991310 (S/N 4953)

Hydraulic System

{not provided} (--- GAL)

Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

All component wear rates are normal.


Contamination

There is a moderate amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		PH0002621		
Sample Date		Client Info		31 Mar 2024		
Machine Age	days	Client Info		0		
Oil Age	days	Client Info		0		
Oil Changed		Client Info		N/A		
Sample Status				ATTENTION		
CONTAMINATION	VI.	method	limit/base	current	history1	history2
Water	V	WC Method	>0.05	NEG		
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>20	<1		
Chromium	ppm	ASTM D5185m	>20	<1		
Nickel	ppm	ASTM D5185m	>20	<1		
Titanium	ppm	ASTM D5185m		<1		
Silver	ppm	ASTM D5185m		0		
Aluminum	ppm		>20	2		
Lead	ppm	ASTM D5185m	>20	1		
Copper	ppm	ASTM D5185m	>20	1		
Tin	ppm	ASTM D5185m	>20	1		
Vanadium	ppm	ASTM D5185m		<1		
Cadmium	ppm	ASTM D5185m		<1		
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		1		
Barium	ppm	ASTM D5185m		0		
Molybdenum	ppm	ASTM D5185m		2		
Manganese	ppm	ASTM D5185m		<1		
Magnesium	ppm	ASTM D5185m		4		
Calcium	ppm	ASTM D5185m		80		
Phosphorus	ppm	ASTM D5185m		404		
Zinc	ppm	ASTM D5185m		505		
Sulfur	ppm	ASTM D5185m		1470		
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>15	4		
Sodium	ppm	ASTM D5185m		<1		
Potassium	ppm	ASTM D5185m	>20	1		
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647	>10000	6130		
Particles >6µm		ASTM D7647	>2500	2243		
Particles >14µm		ASTM D7647	>320	482		
Particles >21µm		ASTM D7647	>80	208		
Particles >38µm		ASTM D7647	>20	24		
Particles >71µm		ASTM D7647	>4	1		
Oil Cleanliness		ISO 4406 (c)	>20/18/15	20/18/16		
FLUID DEGRADA	TION _	method	limit/base	current	history1	history2
Acid Number (AN)	ma KOH/a	ΔSTM D8045		0.68		




Acid Number (AN) mg KOH/g ASTM D8045

Contact/Location: WILLIAM COIN - GULSAV



OIL ANALYSIS REPORT







Certificate L2367

Sample No.

: PH0002621

Lab Number : 06135607 Unique Number : 10955072

Received **Tested**

Diagnosed Test Package: PLANT (Additional Tests: PrtFilter)

: 01 Apr 2024 : 04 Apr 2024 : 04 Apr 2024 - Jonathan Hester

500 GULFSTREAM ROAD SAVANNAH, GA US 31408

Contact: WILLIAM COIN william.coin@gulfstream.com

T: (912)965-8814

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

F: (912)965-5179

Contact/Location: WILLIAM COIN - GULSAV