

OIL ANALYSIS REPORT

Area **THUNDER SPIRIT** [200009532] **28WEA84026 (S/N 72802187428)**

Wind Turbine Gearbox

Fluid CASTROL OPTIGEAR SYNTHETIC X 320 (--- QTS)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of silt (particulates < 14 microns in size) present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

QTS) mikolis Augkolis Augkolis Maykolis Maykolis Deekkoo Jukkolis Jankoos								
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2		
Sample Number		Client Info		NX015545	NX013651	NX013591		
Sample Date		Client Info		18 Mar 2024	14 Nov 2023	12 Jun 2023		
Machine Age	hrs	Client Info		41563	54918	500		
Oil Age	hrs	Client Info		0	0	0		
Oil Changed		Client Info		N/A	N/A	N/A		
Sample Status				ATTENTION	ABNORMAL	NORMAL		
WEAR METALS		method	limit/base	current	history1	history2		
PQ		ASTM D8184	>80	24	21	11		
Iron	ppm	ASTM D5185m	>150	53	44	7		
Chromium	ppm	ASTM D5185m	>5	1	<1	0		
Nickel	ppm	ASTM D5185m	>10	<1	1	0		
Titanium	ppm	ASTM D5185m	>10	<1	0	0		
Silver	ppm	ASTM D5185m		0	<1	0		
Aluminum	ppm	ASTM D5185m	>10	6	6	0		
Lead	ppm	ASTM D5185m	>20	<1	<1	0		
Copper	ppm	ASTM D5185m	>50	5	1	2		
Tin	ppm	ASTM D5185m	>10	<1	<1	0		
Vanadium	ppm	ASTM D5185m		<1	<1	0		
Cadmium	ppm	ASTM D5185m		<1	<1	0		
ADDITIVES		method	limit/base	current	history1	history2		
Boron	ppm	ASTM D5185m		0	23	0		
Barium	ppm	ASTM D5185m		<1	<1	6		
Molybdenum	ppm	ASTM D5185m	1150	704	728	1055		
Manganese	ppm	ASTM D5185m		1	<1	0		
Magnesium	ppm	ASTM D5185m		5	8	7		
Calcium	ppm	ASTM D5185m	2000	1365	1308	1941		
Phosphorus	ppm	ASTM D5185m	400	351	327	378		
Zinc	ppm	ASTM D5185m	0	0	0	0		
Sulfur	ppm	ASTM D5185m	1850	1996	1868	2437		
CONTAMINANTS	3	method	limit/base	current	history1	history2		
Silicon	ppm	ASTM D5185m	>50	11	8	11		
Sodium	ppm	ASTM D5185m	>20	4	2	0		
Potassium	ppm	ASTM D5185m	>20	2	5	2		
Water	%	ASTM D6304	>0.05	0.011	0.243	0.017		
ppm Water	ppm	ASTM D6304	>500	114	4 2430	178.4		
FLUID CLEANLIN	NESS	method	limit/base	current	history1	history2		
Particles >4µm		ASTM D7647		42546		949		
Particles >6µm		ASTM D7647	>2500	<mark> </mark> 4882		149		
Particles >14µm		ASTM D7647	>320	47		20		
Particles >21µm		ASTM D7647	>80	10		7		
Particles >38µm		ASTM D7647	>20	0		0		
Particles >71µm		ASTM D7647	>4	0		0		
Oil Cleanliness		ISO 4406 (c)	>/18/15	e 23/19/13		17/14/11		
FLUID DEGRADA	ATION	method	limit/base	current	history1	history2		
Acid Number (AN)	ma KOH/a	ASTM D8045	16	1.24	0.61	1.39		

Sample Rating Trend

ISO


Acid Number (AN) mg KOH/g Report Id: NORDEX [WUSCAR] 06135616 (Generated: 04/04/2024 21:36:54) Rev: 1


mg KOH/g ASTM D8045 1.6


1.24 0.61 1.39 Contact/Location: DEVIN LINEHAN - NORDEX





OIL ANALYSIS REPORT













VISUAL		method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	🔺 HEAVY	NONE
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	NEG	0.2%	NEG
Free Water	scalar	*Visual		NEG	NEG	NEG
FLUID PROPERT	IES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445	320	320	320	323
SAMPLE IMAGES	S	method	limit/base	current	history1	history2
Color				a.		



Bottom



:01 Apr 2024

: 03 Apr 2024

300 SOUTH WACKER DRIVE, SUITE 1500 CHICAGO, IL : 04 Apr 2024 - Don Baldridge US 60606 Contact: DEVIN LINEHAN DLinehan@nordex-online.com T: (312)386-4124 Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) F: (312)386-7102

Report Id: NORDEX [WUSCAR] 06135616 (Generated: 04/04/2024 21:36:54) Rev: 1

Certificate 12367

Sample No.

Lab Number : 06135616

Unique Number : 10955081

: NX015545

To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Test Package : IND 2 (Additional Tests: KF, PQ, PrtCount)

Received

Diagnosed

Tested

Contact/Location: DEVIN LINEHAN - NORDEX