


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

KAESER 8501243 (S/N 2318)

Component Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

No corrective action is recommended at this time. Oil and filter change at the time of sampling has been noted. Resample at the next service interval to monitor.

Wear

All component wear rates are normal.

Contamination

There is a high amount of particulates present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		<u> </u>	Nov2023	Mar2024		
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA015015	KCPA010035	
Sample Date		Client Info		26 Mar 2024	16 Nov 2023	
Machine Age	hrs	Client Info		7368	5738	
Oil Age	hrs	Client Info		7368	0	
Oil Changed	1115	Client Info		Changed	N/A	
Sample Status		Ciletit IIIIO		ABNORMAL	ABNORMAL	
Sample Status				ADNONWAL	ADNONIVIAL	
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	1	<1	
Chromium	ppm	ASTM D5185m	>10	<1	0	
Nickel	ppm	ASTM D5185m	>3	<1	<1	
Titanium	ppm	ASTM D5185m	>3	<1	<1	
Silver	ppm	ASTM D5185m	>2	0	0	
Aluminum	ppm	ASTM D5185m	>10	2	2	
Lead	ppm	ASTM D5185m	>10	1	<1	
Copper	ppm	ASTM D5185m	>50	21	17	
Tin	ppm	ASTM D5185m	>10	1	<1	
Vanadium	ppm	ASTM D5185m		<1	0	
Cadmium	ppm	ASTM D5185m		<1	<1	
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	
Barium	ppm	ASTM D5185m	90	0	9	
Molybdenum	ppm	ASTM D5185m	0	1	<1	
Manganese	ppm	ASTM D5185m		<1	<1	
Magnesium	ppm	ASTM D5185m	100	22	23	
Calcium	ppm	ASTM D5185m	0	4	1	
Phosphorus	ppm	ASTM D5185m	0	<1	0	
Zinc	ppm	ASTM D5185m	0	25	7	
Sulfur	ppm	ASTM D5185m	23500	20213	18795	
CONTAMINANTS	;	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	1	<1	
Sodium	ppm	ASTM D5185m		10	0	
Potassium	ppm	ASTM D5185m	>20	6	4	
Water	%	ASTM D6304	>0.05	0.015	△ 0.103	
ppm Water	ppm	ASTM D6304	>500	159	▲ 1030	
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		10966		
Particles >6µm		ASTM D7647	>1300	4611		
Particles >14µm		ASTM D7647	>80	252		
Particles >21µm		ASTM D7647	>20	45		
Particles >38µm		ASTM D7647	>4	2		
Particles >71μm		ASTM D7647	>3	0		
Oil Cleanliness		ISO 4406 (c)	>/17/13	<u>^</u> 21/19/15		
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.32	0.32	



OIL ANALYSIS REPORT





Certificate 12367

Sample No.

Laboratory

: KCPA015015 Lab Number : 06135641 Unique Number : 10955106

Received : 01 Apr 2024 **Tested** Diagnosed

: 03 Apr 2024 : 04 Apr 2024 - Don Baldridge

Test Package : IND 2 (Additional Tests: KF, PrtCount)

To discuss this sample report, contact Customer Service at 1-800-237-1369. st - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) Contact/Location: C. COTTER - TESBOS

Report Id: TESBOS [WUSCAR] 06135641 (Generated: 04/04/2024 21:52:12) Rev: 1

48 INDUSTRIAL DR

Contact: C. COTTER

ccotter@tesla.com

BOSTON, MA

US 02110

T:

F: