


# **OIL ANALYSIS REPORT**

Sample Rating Trend



**NORMAL** 



Machine Id

# KAESER AIRCENTER SX 5 6173732 (S/N 1007)

Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

### Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

### Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.

### **Fluid Condition**

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Nov2018	Oct2020 Feb2022	Feb2023 Aug2023	Mar2024	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA015905	KCPA005715	KCP52472
Sample Date		Client Info		21 Mar 2024	21 Aug 2023	08 Feb 2023
Machine Age	hrs	Client Info		50202	45891	41663
Oil Age	hrs	Client Info		0	0	3000
Oil Changed		Client Info		Changed	N/A	Changed
Sample Status				NORMAL	NORMAL	ATTENTION
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	0	0
Chromium	ppm	ASTM D5185m	>10	<1	0	0
Nickel	ppm	ASTM D5185m	>3	<1	0	0
Titanium	ppm	ASTM D5185m	>3	<1	0	0
Silver	ppm	ASTM D5185m	>2	0	0	0
Aluminum	ppm	ASTM D5185m	>10	2	<1	0
Lead	ppm	ASTM D5185m	>10	<1	0	0
Copper	ppm	ASTM D5185m	>50	2	1	1
Tin	ppm	ASTM D5185m	>10	1	0	0
Antimony	ppm	ASTM D5185m				
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		<1	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	0
Barium	ppm	ASTM D5185m	90	6	18	9
Molybdenum	ppm	ASTM D5185m	0	<1	0	0
Manganese	ppm	ASTM D5185m		<1	<1	0
Magnesium	ppm	ASTM D5185m	100	36	47	40
Calcium	ppm	ASTM D5185m	0	4	0	<1
Phosphorus	ppm	ASTM D5185m	0	2	3	4
Zinc	ppm	ASTM D5185m	0	0	0	3
Sulfur	ppm	ASTM D5185m	23500	22241	22643	19883
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m		<1	<1	<1
Sodium	ppm	ASTM D5185m	0	6	10	11
Potassium	ppm	ASTM D5185m	>20	2	<1	<1
Water	%	ASTM D6304		0.016	0.012	0.014
ppm Water	ppm	ASTM D6304	>500	162	128.2	148.9
FLUID CLEANLIN		method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		406	1581	3988
Particles >6μm		ASTM D7647	>1300	131	449	1573
Particles >14µm		ASTM D7647	>80	15	35	109
Particles >21µm		ASTM D7647	>20	4	8	18
Particles >38µm		ASTM D7647	>4	0	0	1
Particles >71µm		ASTM D7647		0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	16/14/11	18/16/12	19/18/14
	<b>T</b> 1044					
FLUID DEGRADA	TION	method				history2



## OIL ANALYSIS REPORT







Certificate 12367

Laboratory Sample No. Lab Number

: 06135653 Unique Number: 10955118

: KCPA015905

: WearCheck USA - 501 Madison Ave., Cary, NC 27513 Received : 01 Apr 2024 Tested : 03 Apr 2024

Diagnosed : 04 Apr 2024 - Don Baldridge

Test Package : IND 2 ( Additional Tests: KF, PrtCount ) To discuss this sample report, contact Customer Service at 1-800-237-1369.

\* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

**PROTEUS INDUSTRIES** 340 PIONEER WAY

MOUNTAIN VIEW, CA US 94041 Contact: P. QUINATA

p\_quinata@proteusind.com T:

F: