


OIL ANALYSIS REPORT

Sample Rating Trend



Machine Id

7921402 (S/N 1348)Component Compressor

KAESER SIGMA (OEM) M-460 (--- GAL)

DIAGNOSIS

Recommendation

Oil and filter change at the time of sampling has been noted. We recommend an early resample in 500 hours to monitor this condition.

All component wear rates are normal.

Contamination

There is a moderate amount of particulates present in the oil. There is a light concentration of water present in the oil.


Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

		Jur	2023	Oct2023 Mar203	24	
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KCPA014952	KCPA007795	KCPA002227
Sample Date		Client Info		27 Mar 2024	16 Oct 2023	06 Jun 2023
Machine Age	hrs	Client Info		10203	8402	7279
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		Changed	N/A	N/A
Sample Status				ABNORMAL	ABNORMAL	ABNORMAL
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	3	2	0
Chromium	ppm	ASTM D5185m	>10	<1	0	0
Nickel	ppm	ASTM D5185m	>3	<1	2	0
Titanium	ppm	ASTM D5185m	>3	<1	0	<1
Silver	ppm	ASTM D5185m	>2	0	<1	0
Aluminum	ppm	ASTM D5185m	>10	2	2	<1
Lead	ppm	ASTM D5185m	>10	1	0	0
Copper	ppm	ASTM D5185m	>50	7	4	7
Tin	ppm	ASTM D5185m	>10	1	<1	0
Vanadium	ppm	ASTM D5185m		<1	<1	0
Cadmium	ppm	ASTM D5185m		<1	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0	0
Barium	ppm	ASTM D5185m	90	8	2	0
Molybdenum	ppm	ASTM D5185m	0	<1	0	0
Manganese	ppm	ASTM D5185m		<1	<1	0
Magnesium	ppm	ASTM D5185m	100	28	33	0
Calcium	ppm	ASTM D5185m	0	4	1	0
Phosphorus	ppm	ASTM D5185m	0	5	<1	0
Zinc	ppm	ASTM D5185m	0	1	3	0
Sulfur	ppm	ASTM D5185m	23500	21672	20531	17441
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	4	<1	<1
Sodium	ppm	ASTM D5185m		11	6	0
Potassium	ppm	ASTM D5185m	>20	3	6	0
Water	%	ASTM D6304	>0.05	△ 0.123	0.013	0.009
ppm Water	ppm	ASTM D6304	>500	1226	134.8	91.4
FLUID CLEANLIN	IESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		896	26042	5810
Particles >6µm		ASTM D7647	>1300	488	<u></u> 6141	2 063
Particles >14µm		ASTM D7647	>80	83	<u>^</u> 211	<u> </u>
Particles >21µm		ASTM D7647	>20	_ 28	<u></u> 59	<u>▲</u> 51
Particles >38µm		ASTM D7647	>4	4	2	1
Particles >71µm		ASTM D7647		0	0	0
Oil Cleanliness		ISO 4406 (c)	>/17/13	17/16/14	<u>22/20/15</u>	<u>20/18/15</u>
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	1.0	0.40	0.38	0.43



OIL ANALYSIS REPORT







Certificate 12367

Laboratory Sample No.

: WearCheck USA - 501 Madison Ave., Cary, NC 27513

: KCPA014952 : 06135654

Lab Number Unique Number: 10955119

Received : 01 Apr 2024 **Tested** : 08 Apr 2024 Diagnosed : 08 Apr 2024 - Jonathan Hester

Test Package : IND 2 (Additional Tests: KF, PrtCount) To discuss this sample report, contact Customer Service at 1-800-237-1369.

 st - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact: TYLER tyler@stgmachine.com T:

Report Id: STGSAN [WUSCAR] 06135654 (Generated: 04/08/2024 11:33:17) Rev: 1

Contact/Location: TYLER ? - STGSAN

481 GIANNI ST

US 95054

F:

SANTA CLARA, CA