




OIL ANALYSIS REPORT

Sample Rating Trend



WATER



Machine Id
KAESER SM 15 2712688 (S/N 1002)
 Component
Compressor
 Fluid
KAESER SIGMA (OEM) S-460 (--- QTS)

DIAGNOSIS

Recommendation

The filter change at the time of sampling has been noted. We advise that you stop the unit and follow the water drain-off procedure for this component. We recommend an early resample in 500 hours to monitor this condition.

Wear

All component wear rates are normal.

Contamination

There is a moderate amount of particulates present in the oil. There is a light concentration of water present in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

SAMPLE INFORMATION

	method	limit/base	current	history1	history2
Sample Number	Client Info		KCPA016972	KCP55568	KCP43392
Sample Date	Client Info		28 Mar 2024	10 Feb 2023	09 Nov 2021
Machine Age	hrs	Client Info	32698	32042	27359
Oil Age	hrs	Client Info	3200	4683	2794
Oil Changed	Client Info		Not Changed	Changed	Changed
Sample Status			ABNORMAL	ABNORMAL	ABNORMAL

WEAR METALS

	method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m >50	<1	<1	0
Chromium	ppm	ASTM D5185m >10	<1	0	0
Nickel	ppm	ASTM D5185m >3	<1	<1	0
Titanium	ppm	ASTM D5185m >3	<1	0	0
Silver	ppm	ASTM D5185m >2	0	0	<1
Aluminum	ppm	ASTM D5185m >10	2	<1	0
Lead	ppm	ASTM D5185m >10	1	<1	<1
Copper	ppm	ASTM D5185m >50	3	4	2
Tin	ppm	ASTM D5185m >10	1	0	0
Antimony	ppm	ASTM D5185m	---	---	0
Vanadium	ppm	ASTM D5185m	<1	0	0
Cadmium	ppm	ASTM D5185m	<1	0	0

ADDITIVES

	method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m	0	0	0
Barium	ppm	ASTM D5185m 90	11	7	2
Molybdenum	ppm	ASTM D5185m	<1	0	0
Manganese	ppm	ASTM D5185m	<1	<1	<1
Magnesium	ppm	ASTM D5185m 90	53	56	64
Calcium	ppm	ASTM D5185m 2	5	2	0
Phosphorus	ppm	ASTM D5185m	2	0	3
Zinc	ppm	ASTM D5185m	<1	12	8
Sulfur	ppm	ASTM D5185m	23523	20516	16438

CONTAMINANTS

	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m >25	1	<1	0
Sodium	ppm	ASTM D5185m	9	13	0
Potassium	ppm	ASTM D5185m >20	5	8	7
Water	%	ASTM D6304 >0.05	▲ 0.322	0.015	0.027
ppm Water	ppm	ASTM D6304 >500	▲ 3218	154.4	275.1






FLUID CLEANLINESS

	method	limit/base	current	history1	history2
Particles >4µm	ASTM D7647		1583	15799	13960
Particles >6µm	ASTM D7647 >1300		863	▲ 3693	▲ 3810
Particles >14µm	ASTM D7647 >80		● 147	▲ 169	▲ 294
Particles >21µm	ASTM D7647 >20		● 49	▲ 41	▲ 61
Particles >38µm	ASTM D7647 >4		● 8	2	4
Particles >71µm	ASTM D7647 >3		1	0	0
Oil Cleanliness	ISO 4406 (c) >17/13		● 17/14	▲ 19/15	▲ 19/15

FLUID DEGRADATION

	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045 0.4	0.35	0.35	0.396


OIL ANALYSIS REPORT






VISUAL	method	limit/base	current	history1	history2
White Metal	scalar	*Visual	NONE	NONE	NONE
Yellow Metal	scalar	*Visual	NONE	NONE	NONE
Precipitate	scalar	*Visual	NONE	NONE	NONE
Silt	scalar	*Visual	NONE	NONE	NONE
Debris	scalar	*Visual	NONE	NONE	LIGHT
Sand/Dirt	scalar	*Visual	NONE	NONE	NONE
Appearance	scalar	*Visual	NORML	NORML	NORML
Odor	scalar	*Visual	NORML	NORML	NORML
Emulsified Water	scalar	*Visual	>0.05	0.2%	NEG
Free Water	scalar	*Visual		NEG	NEG

FLUID PROPERTIES	method	limit/base	current	history1	history2
Visc @ 40°C	cSt	ASTM D445 46	45.7	48.0	50.2

SAMPLE IMAGES	method	limit/base	current	history1	history2
---------------	--------	------------	---------	----------	----------



GRAPHS



Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : KCPA016972 **Received** : 01 Apr 2024
Lab Number : 06135666 **Tested** : 08 Apr 2024
Unique Number : 10955131 **Diagnosed** : 08 Apr 2024 - Jonathan Hester
Test Package : IND 2 (Additional Tests: KF, PrtCount)

PENSKE TRUCKING
 818 PEACH STREET
 POPLAR BLUFF, MO
 US 63901
 Contact: SERVICE MANAGER

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:
F: