


OIL ANALYSIS REPORT

Sample Rating Trend



NORMAL



Machine Id

7888963 (S/N 1645)

Compressor

KAESER SIGMA (OEM) S-460 (--- GAL)

Recommendation

Resample at the next service interval to monitor.

All component wear rates are normal.

Contamination

The amount and size of particulates present in the system are acceptable. There is no indication of any contamination in the oil.

Fluid Condition

The AN level is acceptable for this fluid. The condition of the oil is suitable for further service.

	Ju6022 Jm2023 Mm2024					
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		KC121611	KC97115	KC92861
Sample Date		Client Info		15 Mar 2024	04 Jan 2023	11 Jul 2022
Machine Age	hrs	Client Info		2591	626	238
Oil Age	hrs	Client Info		0	406	238
Oil Changed		Client Info		N/A	Not Changd	Changed
Sample Status				NORMAL	ABNORMAL	ATTENTION
WEAR METALS		method	limit/base	current	history1	history2
Iron	ppm	ASTM D5185m	>50	<1	0	0
Chromium	ppm	ASTM D5185m	>10	<1	0	0
Nickel	ppm	ASTM D5185m	>3	<1	0	0
Titanium	ppm	ASTM D5185m	>3	<1	0	0
Silver	ppm	ASTM D5185m	>2	<1	0	<1
Aluminum	ppm	ASTM D5185m	>10	2	0	0
Lead	ppm	ASTM D5185m	>10	1	<1	<1
Copper	ppm	ASTM D5185m	>50	2	<1	1
Tin	ppm	ASTM D5185m	>10	1	0	0
Vanadium	ppm	ASTM D5185m		<1	0	0
Cadmium	ppm	ASTM D5185m		<1	0	0
ADDITIVES		method	limit/base	current	history1	history2
Boron	ppm	ASTM D5185m		0	0	0
Barium	ppm	ASTM D5185m	90	18	15	<1
Molybdenum	ppm	ASTM D5185m		<1	0	0
Manganese	ppm	ASTM D5185m		<1	0	<1
Magnesium	ppm	ASTM D5185m	90	71	36	43
Calcium	ppm	ASTM D5185m	2	5	<1	0
Phosphorus	ppm	ASTM D5185m		4	9	14
Zinc	ppm	ASTM D5185m		3	2	2
CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	>25	<1	2	<1
Sodium	ppm	ASTM D5185m		12	3	7
Potassium	ppm	ASTM D5185m	>20	6	8	16
Water	%	ASTM D6304	>0.05	0.029	△ 0.157	0.024
ppm Water	ppm	ASTM D6304	>500	297	<u> </u>	245.4
FLUID CLEANLIN	ESS	method	limit/base	current	history1	history2
Particles >4µm		ASTM D7647		3373		4579
Particles >6μm		ASTM D7647	>1300	873		1321
Particles >14μm		ASTM D7647	>80	47		57
Particles >21µm		ASTM D7647		9		8
Particles >38µm		ASTM D7647	>4	0		1
Particles >71μm		ASTM D7647		0		0
Oil Cleanliness		ISO 4406 (c)	>/17/13	19/17/13		<u> </u>
FLUID DEGRADA	TION	method	limit/base	current	history1	history2
Acid Number (AN)	mg KOH/g	ASTM D8045	0.4	0.44	0.28	0.34



OIL ANALYSIS REPORT





Certificate 12367

Sample No. Lab Number Unique Number : 10955141

: KC121611 : 06135676

Received **Tested** Test Package : IND 2

: 01 Apr 2024 : 03 Apr 2024 Diagnosed : 04 Apr 2024 - Don Baldridge

4441 US HWY 27 S SEBRING, FL US 33870

Contact: Service Manager

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

T:

F: