




FUEL REPORT

Sample Rating Trend



NORMAL



Area
[20240794]
 Machine Id
Kohler 300 NJ Ave
 Component
Diesel Fuel
 Fluid
{not provided} (75 GAL)

DIAGNOSIS

Recommendation

All laboratory tests indicate that this sample meets specifications for No.2 ultra-low-sulfur diesel fuel.

Corrosion

All metal levels are normal indicating no corrosion in the system.

Contaminants

The water content is negligible. There is no bacteria or fungus (yeast and/or mold) indicated in the sample. There is no indication of any contamination in the fuel.

Fuel Condition

Sulfur value derived by ASTM D5453 method for ULSD validation. Sulfur level is acceptable for ULSD specification.

SAMPLE INFORMATION		method	limit/base	current	history1	history2
Sample Number	Client Info			DC0030702	DC0024954	---
Sample Date	Client Info			11 Mar 2024	21 Mar 2023	---
Machine Age	yrs	Client Info		0	0	---
Sample Status				NORMAL	ABNORMAL	---



PHYSICAL PROPERTIES		method	limit/base	current	history1	history2
ASTM Color	scalar	*ASTM D1500		L4.0	L4.5	---
Visc @ 40°C	cSt	ASTM D445		2.63	2.63	---

SULFUR CONTENT		method	limit/base	current	history1	history2
Sulfur	ppm	ASTM D5185m		3	9	---
Sulfur (UVF)	ppm	ASTM D5453		8	11	---

IGNITION QUALITY		method	limit/base	current	history1	history2
API Gravity		ASTM D7777		36.4	---	---


CONTAMINANTS		method	limit/base	current	history1	history2
Silicon	ppm	ASTM D5185m	<1.0	<1	<1	---
Sodium	ppm	ASTM D5185m	<0.1	1	0	---
Potassium	ppm	ASTM D5185m	<0.1	0	<1	---
Water	%	ASTM D6304	<0.05	0.003	0.003	---
ppm Water	ppm	ASTM D6304	<500	35	25.5	---
% Gasoline	%	*In-House	<0.50	0.0	0.0	---
% Biodiesel	%	*In-House	<20.0	0.0	0.0	---

HEAVY METALS		method	limit/base	current	history1	history2
Aluminum	ppm	ASTM D5185m	<0.1	0	<1	---
Nickel	ppm	ASTM D5185m	<0.1	0	0	---
Lead	ppm	ASTM D5185m	<0.1	0	0	---
Vanadium	ppm	ASTM D5185m	<0.1	0	0	---
Iron	ppm	ASTM D5185m	<0.1	0	0	---
Calcium	ppm	ASTM D5185m	<0.1	0	1	---
Magnesium	ppm	ASTM D5185m	<0.1	0	<1	---
Phosphorus	ppm	ASTM D5185m	<0.1	0	11	---
Zinc	ppm	ASTM D5185m	<0.1	0	0	---


SAMPLE IMAGES		method	limit/base	current	history1	history2
Color						 <i>no image</i>
Bottom						 <i>no image</i>



FUEL REPORT



GRAPHS



Certificate L2367

Laboratory : WearCheck USA - 501 Madison Ave., Cary, NC 27513
Sample No. : DC0030702 **Received** : 01 Apr 2024
Lab Number : 06135941 **Tested** : 12 Apr 2024
Unique Number : 10955406 **Diagnosed** : 12 Apr 2024 - Doug Bogart
Test Package : DF-5 (Additional Tests: API, Cetane, Fuel, Screen)

To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation.

Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

JE RICHARDS
 4600 HARGROVE DR
 LANHAM, MD
 US 20706
 Contact: E. NOEL
 enoel@phalconusa.com
 T: (240)623-4398
 F: