

COOLANT REPORT

Area THUNDER SPIRIT [200009532] 28WEA84026 - CONVERTER (S/N 72802187428)

Coolant

Fluid **INTERCOOL W6F-55AA (--- QTS)**

Recommendation

The fluid is suitable for further service.

Corrosion


All metal levels are normal indicating no corrosion in the cooling system.

Contaminants

There is no indication of any contamination in the coolant.

Coolant Condition

Glycol and nitrite levels are acceptable. The pH level of this fluid is within the acceptable limits.




Sample Rating Trend




SAMPLE INFORM	ATION	method	limit/base	current	history1	history2
Sample Number		Client Info		NX014479	NX004424	
Sample Date		Client Info		01 Apr 2024	09 May 2022	
Machine Age	hrs	Client Info		41563	0	
Oil Age	hrs	Client Info		0	0	
Oil Changed		Client Info		N/A	N/A	
Sample Status				NORMAL	NORMAL	
PHYSICAL TEST R	ESULTS	method	limit/base	current	history1	history2
Glycol Type		FT-IR				
Specific Gravity		*ASTM D1298		1.079	1.079	
pН	Scale 0-14	ASTM D1287		7.89	7.81	
Nitrites	ppm	AP-053:2009		1124	600	
Reserve Alkalinity	Scale 0-20	*ASTM D1121				
Percentage Glycol	%	ASTM D3321		59.6	59.6	
Freezing Point	°F	ASTM D3321		-56	-56	
Total Dissolved Solids				258.5	327.0	
Carboxylate				n/a	n/a	
CORROSION INH	IBITORS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D6130		14	21	
Phosphorus	ppm	ASTM D6130		1503	1088	
Boron	ppm	ASTM D6130		275	437	
Molybdenum	ppm	ASTM D6130		2	2	
CORROSION		method	limit/base	current	history1	history2
Iron	ppm	ASTM D6130	>15	3	0	
Aluminum	ppm	ASTM D6130	>10	<1	0	
Copper	ppm	ASTM D6130	>10	0	<1	
Lead	ppm	ASTM D6130	>10	0	0	
Tin	ppm	ASTM D6130	>10	0	0	
Zinc	ppm	ASTM D6130		0	0	
CONTAMINANTS		method	limit/base	current	history1	history2
Chlorine	ppm	ASTM D6130		21	0	
CARRIER SALTS		method	limit/base	current	history1	history2
Sodium	ppm	ASTM D6130		373	343	
Potassium	ppm	ASTM D6130		4818	2389	
SCALE POTENTI	AL	method	limit/base	current	history1	history2
Calcium	ppm	ASTM D6130	>100	0	0	
Magnesium	ppm	ASTM D6130	>40	0	2	
Hardness	mg/L CaCO3	*In-house	<75	0		
	v					



COOLANT REPORT







Unique Number : 10955444 Diagnosed : 05 Apr 2024 - Jonathan Hester Test Package : COOL (Additional Tests: GlycolType) Contact: BRIAN DOBBINS Certificate 12367 bdobbins@nordex-online.com To discuss this sample report, contact Customer Service at 1-800-237-1369. * - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012)

Contact/Location: BRIAN DOBBINS - NORDEX

T: (312)386-4100

F: (312)386-7102