

COOLANT REPORT


Area

THUNDER SPIRIT [200009532] 15WEA84034 - CONVERTER (S/N 72802187630)

Coolant

Fluid

INTERCOOL ETHYLENE GLYCOL (--- QTS)





DIAGNOSIS

Recommendation

The fluid is suitable for further service.

Corrosion

All metal levels are normal indicating no corrosion in the cooling system.

Contaminants

There is no indication of any contamination in the coolant.


Coolant Condition


Glycol and nitrite levels are acceptable. The pH level of this fluid is within the acceptable limits.


	Mw/2022 Judaz2 Mw/2024					
SAMPLE INFORM	MATION	method	limit/base	current	history1	history2
Sample Number		Client Info		NX014495	NX009480	NX004471
Sample Date		Client Info		18 Mar 2024	07 Jul 2022	06 May 2022
Machine Age	hrs	Client Info		57489	0	0
Oil Age	hrs	Client Info		0	0	0
Oil Changed		Client Info		N/A	N/A	N/A
Sample Status				NORMAL	SEVERE	NORMAL
PHYSICAL TEST R	ESULTS	method	limit/base	current	history1	history2
Glycol Type		FT-IR				
Specific Gravity		*ASTM D1298		1.075	1.075	1.079
рН	Scale 0-14	ASTM D1287		8.36	8.96	7.84
Nitrites	ppm	AP-053:2009		712	300	372
Reserve Alkalinity	Scale 0-20	*ASTM D1121				
Percentage Glycol	%	ASTM D3321		55.7	55.7	59.3
Freezing Point	°F	ASTM D3321		-47	-47	-56
Total Dissolved Solids				281.5	251.5	324.0
Carboxylate				n/a	n/a	n/a
CORROSION INHI	BITORS	method	limit/base	current	history1	history2
Silicon	ppm	ASTM D6130		19	154	19
Phosphorus	ppm	ASTM D6130		1268	853	1151
Boron	ppm	ASTM D6130		249	308	432
Molybdenum	ppm	ASTM D6130		72	272	1
CORROSION		method	limit/base	current	history1	history2
Iron	ppm	ASTM D6130	>15	5	1 79	0
Aluminum	ppm	ASTM D6130	>10	<1	<u> </u>	0
Copper	ppm	ASTM D6130	>10	0	<1	<1
Lead	ppm	ASTM D6130	>10	0	0	0
Tin	ppm	ASTM D6130	>10	0	0	0
Zinc	ppm	ASTM D6130		0	6	0
CONTAMINANTS		method	limit/base	current	history1	history2
Chlorine	ppm	ASTM D6130		20	23	0
CARRIER SALTS		method	limit/base	current	history1	history2
Sodium	ppm	ASTM D6130		544	526	347
Potassium	ppm	ASTM D6130		4190	1950	2491
SCALE POTENTI	AL	method	limit/base	current	history1	history2
Calcium	ppm	ASTM D6130	>100	0	0	0
Magnesium	ppm	ASTM D6130	>40	0	<1	2
Hardness	mg/L CaCO3	*In-house	<75	0	0	



COOLANT REPORT









Laboratory Sample No.

: NX014495 Lab Number : 06135981 Unique Number : 10955446

: WearCheck USA - 501 Madison Ave., Cary, NC 27513

Received : 01 Apr 2024 **Tested** : 05 Apr 2024 Diagnosed

: 05 Apr 2024 - Jonathan Hester

NORDEX USA - Chicago 300 SOUTH WACKER DRIVE, SUITE 1500

CHICAGO, IL US 60606 Contact: DEVIN LINEHAN

DLinehan@nordex-online.com T: (312)386-4124

Test Package : COOL (Additional Tests: GlycolType) Certificate 12367 To discuss this sample report, contact Customer Service at 1-800-237-1369.

* - Denotes test methods that are outside of the ISO 17025 scope of accreditation. Statements of conformity to specifications are based on the simple acceptance decision rule (JCGM 106:2012) F: (312)386-7102